

THIS REPORT HAS BEEN DELIMITED
AND CLEARED FOR PUBLIC RELEASE
UNDER DOD DIRECTIVE 5200.20 AND
NO RESTRICTIONS ARE IMPOSED UPON
ITS USE AND DISCLOSURE.

DISTRIBUTION STATEMENT A

APPROVED FOR PUBLIC RELEASE;
DISTRIBUTION UNLIMITED.

UNCLASSIFIED

A 204074

Armed Services Technical Information Agency

ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA

FOR
MICRO-CARD
CONTROL ONLY

1 OF 5

NOTICE: WHEN GOVERNMENT OR OTHER DRAWINGS, SPECIFICATIONS OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY RELATED GOVERNMENT PROCUREMENT OPERATION, THE U. S. GOVERNMENT THEREBY INCURS NO RESPONSIBILITY, NOR ANY OBLIGATION WHATSOEVER; AND THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED, FURNISHED, OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA IS NOT TO BE REGARDED BY IMPLICATION OR OTHERWISE AS IN ANY MANNER LICENSING THE HOLDER OR ANY OTHER PERSON OR CORPORATION, OR CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

UNCLASSIFIED

This report is unclassified
according to US Security Regs.

MORTON ALPERIN
Director of Advanced
Studies

AFOSR
11 June 1957

AD NO. 204 074
ASTIA FILE COPY

FILE COPY

Return to

ASTIA

ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA

Attn: TISS

AF 64-1409
FINAL REPORT

BEST

AVAILABLE

COPY

P A R T I I

T E S T S .

•
• •


au "CENTRE COMDA" - VALPAIRE.

a) Etude comparative de tuyères.

Ceci réalisé, on a, pour une même famille de tuyères homothétiques ou semblables, comparé les performances de ces différentes tuyères.

Nous nous sommes également efforcés d'effectuer, autant que possible, une étude qualitative de ces tuyères.

Les tuyères COANDA sont de trois types différents (Figures ci-dessous) :



GENERAL CONDITIONS OF THE TESTS MADE
AT THE "COANDA CENTER", MALPAIRE.

The tests which were carried out in the conditions and gave the results to be described below were performed in execution of Contract No. AF 6I (514) I409. Owing to the short time at our disposal, they had to be carried out in rapid succession so that we were faced with considerable difficulties in collecting the material equipment and the personnel required.

•
••

I. PURPOSE OF THE TESTS :

a) Comparative study of nozzles.

One of the objects of the tests was to make a comparative study, for a given nozzle, of various different adjustments possible, obtained by varying the feed pressure and the dimensions of the slot opening.


Having done this, we compared the performance of different nozzles belonging to the same category of homothetic or similar nozzles.

Finally, on the basis of the above-mentioned tests we were able to deduce which category of nozzles had the highest efficiency.

We also tried to make a qualitative study of the nozzles.

b) Terminology and definitions.

COANDA nozzles are of three different types, as shown in the figures below :



- Tuyères externes, extrêmement intéressantes pour l'expérimentation théorique mais sans intérêt pour l'Aérodyn.
- Tuyères internes, qui ont fait l'objet de ces essais.
- Tuyères du type "L.A.", sur lesquelles ont été effectués d'autres essais.

Description générale d'une tuyère interne COANDA :

Une tuyère interne COANDA se compose :

- d'un convergent-divergent présentant un col.
- Le convergent débute par une lèvre dite fixe, à facettes ou à profil continu. La coupe de cette lèvre est appelée profil. L'ensemble est entouré d'un corps concentrique, l'intervalle entre le corps de la tuyère et le système convergent-divergent formant la chambre de la tuyère.
- Cette chambre est fermée du côté convergent par un volume torique se vissant sur le corps. C'est le chapeau de la tuyère, dont la partie venant buter avec la lèvre fixe est appelée lèvre mobile.
- En dévissant le chapeau, les deux lèvres s'écartent et leur plus courte distance est appelée ouverture réelle : cette ouverture réelle n'est pas toujours facile à mesurer directement, et on préfère introduire une ouverture dite "au pas", qui représente le déplacement du chapeau lorsqu'on le dévisse. La correspondance entre l'ouverture réelle et l'ouverture au pas est donnée pour chaque tuyère par un tableau.

c) Présentation des tuyères essayées :

Les tuyères sont groupées par familles. A l'intérieur d'une famille les tuyères peuvent être soit homothétiques (pour une ouverture nulle), soit semblables, c'est à dire de même section méridienne mais de diamètre au col différent.

Quatre familles de tuyères ont été essayées :

- Une famille de tuyères à facettes homothétiques (ce sont les tuyères I2, I60 et 22).
- Deux familles de tuyères à profil arrondi homothétiques (ce sont respectivement les tuyères I02bis, I62, 202, 302bis, et les tuyères I04, I64, 204 et 304).
- Enfin, une famille de tuyères à profil arrondi semblables (ce sont les tuyères I02, 202 et 302).

Ces tuyères ont été réalisées en aluminium coulé. Ces prototypes, de réalisation très délicate, auraient dû être exécutés en bronze afin d'avoir une régularité rigoureuse des profils et un état de surface meilleur; le prix de revient de telles tuyères nous a fait adopter l'aluminium (matière moins chère, exécution plus rapide). Nous avons pu ainsi faire des essais comparatifs intéressants, cependant il est incontestable que

- External nozzles : of great interest for theoretical experimentation but of no interest as regards the Aerodyne.

- Internal nozzles : used for the tests in question.

- "L.A." type nozzles : used for other tests.

General description of a COANDA internal nozzle :

A COANDA nozzle consists of the following parts :

- a convergent-divergent part presenting a throat.

- the convergent starts with a so-called fixed lip whose profile may be continuous or present successive facets. The cross-section of this lip is called the profile. The whole is surrounded by a concentric body, the space between the body of the nozzle and the convergent-divergent forming the chamber of the nozzle.

- On the convergent side this chamber is closed by a toric element screwed onto the body. This is the cap of the nozzle, and its edge which can be screwed down to touch the fixed lip is called the adjustable lip.

- When this cap is unscrewed, the two lips move apart and the shortest distance between them is called the real opening : this real opening is not always easy to measure directly, so that we prefer to take the so-called "opening by pitch", which measures the movement of the cap by unscrewing this cap. The relation of the real opening to the opening by pitch for each nozzle is given in a table.

c) Nozzles tested.

The nozzles are classified into categories. Within one category the nozzles may be homothetic (for zero opening) or similar, that is to say having the same meridian section but a different diameter of throat.

Four categories of nozzles were tested :

- One category of homothetic nozzles with facets (nozzles I2, I60 and 22).
- Two categories of homothetic nozzles with rounded profiles (nozzles I02b, I62, 202, 302b, and nozzles I04, I64, 204 and 304 respectively).
- One category with similar rounded profiles (nozzles I02, 202 and 302).

These nozzles were cast in aluminium. Their construction was a very tricky job, and these prototypes should have been made of bronze in order to ensure the absolute regularity of the profiles and have a better surface. However, the high cost of such nozzles led us to adopt aluminium as a cheaper material and quicker to work on. We were thus able to make interesting comparative tests; however, it is quite certain that with mate-

des réalisations meilleures d'usinage pourraient améliorer encore sensiblement le phénomène.

Utilisation de la tuyère : De l'air sous pression envoyé dans la chambre de la tuyère, en sort par la fente entre la lèvre mobile et la lèvre fixe. Le débit de cet air est appelé débit primaire. Le jet que constitue l'air primaire suit le profil de la tuyère en aspirant de l'air ambiant et le tout passe à travers le convergent-divergent. Le débit mesuré à la sortie du divergent est appelé débit total, lequel se compose donc de l'air primaire (débit primaire) et de l'air aspiré (air secondaire). Le rapport du débit total au débit primaire est appelé "induction". Le flux de quantité de mouvement ainsi créé exerce une force sur la tuyère. La composante de cette force suivant l'axe de la tuyère est appelée "traction".

d) Mesures :

Les mesures que l'on se proposait de faire étaient les suivantes :

- pression le long de la lèvre fixe,
- débit primaire,
- débit total,
- traction,
- température dans la chambre de la tuyère,
- température à la sortie du divergent,
- vitesse à la sortie du divergent,
- température du jet à la sortie de la fente,

toutes ces mesures pour différents réglages d'ouvertures et de pressions dans la chambre de la tuyère.

II. METHODE OPERATOIRE :

- a) Installation générale du banc d'essais. { Les numéros mis entre parenthèses renvoient au schéma du banc d'essais. }

Le banc d'essais comprenait :

- Trois compresseurs de 25, 10, 7,5 CV., montés en série, débitant environ 0,45 Kg. d'air par seconde.

Cet air était accumulé dans deux réservoirs d'un volume total de 6 m³., pouvant supporter une pression de 7 Kgs./cm² (I8 et I9). Ces réservoirs étaient en liaison avec un réservoir dit "réservoir tampon" d'une capacité de 2 m³ (I5), dans lequel on s'arrangeait, par manoeuvres de vannes, pour avoir une pression constante de 4,5 Kgs./cm². De ce réservoir tampon l'air traversait deux débitmètres de sensibilité différente (I4 et I5). Cet air passait ensuite dans un petit réservoir destiné à homogénéiser les caractéristiques physiques de la veine. L'air traversait alors un joint tournant (4), puis se rendait dans la chambre de la tuyère : celle-ci était suspendue à une balance pendulaire (6).

- b) Mesure du débit primaire :

La gamme des essais nécessitait deux sensibilités de débitmètres qui furent montés en parallèle. D'abord un débitmètre à diaphragme "BERI" (I4), qui dans les conditions des essais (pression au diaphragme de l'ordre de

rial allowing of better machining the efficiency of the phenomenon could be still further increased.

Operation of the nozzle : Compressed air is sent into the chamber of the nozzle and emerges from the slot between the adjustable lip and the fixed lip. The air discharged through the slot is called the primary flow (primary air). The jet of primary air follows the profile of the nozzle, on its way inducing part of the surrounding air, and the resulting mixture passes through the convergent-divergent. The discharge measured at the exit of the divergent is called the total flow and thus consists of the primary air (primary flow) and induced air (secondary air). The ratio of the total flow to the primary flow is called the "induction". The momentum flux thus created exerts a force on the nozzle. The component of this force along the axis of the nozzle is called the thrust (referred to in the tables as traction).

d) Measurements :

The measurements undertaken were as follows :

- pressure along the fixed lip,
- primary flow,
- total flow,
- traction,
- temperature in the nozzle chamber,
- temperature at the exit of the divergent,
- velocity at the exit of the divergent,
- temperature of the jet at the exit of the slot,

all these measurements being taken for a series of different openings and pressures in the chamber of the nozzle.

II. OPERATIONAL PROCEDURE :

- a) General equipment of the test bench. (The numbers in brackets are for reference to the test bench diagram.)

The test bench contained the following :

- Three compressors of 25, 10, 7,5 hp, mounted in series, their approximate output being 0.45 Kg of air per second.

This air was collected in two reservoir tanks having a total volume of 6 cubic meters, able to stand a pressure of 7 kg/cm² (I8 and I9). These reservoirs were connected to a so-called "buffer tank" of 2 cubic meters capacity (I5), in which by means of a system of cocks we maintained a constant pressure of 4.5 kg/cm². Coming from this buffer tank, the air passed through two flow meters of different sensitivity (I4 and I5). This air then passed into a small tank the purpose of which was to homogenize the physical characteristics of the stream. Then the air flowed through a turning joint (4) and went on into the nozzle chamber. The nozzle was suspended on a swing balance (I6).

- b) Measurement of the primary flow :

The range of tests undertaken made it necessary to have flow meters of two sensibilities, which were mounted in parallel. First there was a "BERI" flow meter with diaphragm, which in the conditions prevailing

4,5 Kgs./cm² à 20°) pouvait mesurer un débit de 50 à 500 grammes par seconde. Ensuite, un débitmètre à diaphragme aussi, du type gyromètre "Houdec" (II), qui, toujours sous les conditions des essais, pouvait mesurer un débit de 250 à 1.300 grammes par seconde.

c) Mesure des Températures :

Les températures au niveau des débitmètres étaient mesurées par des thermomètres spéciaux à mercure (I3).

La température au niveau de la tuyère était mesurée par des thermo-couples B.T.E. - C.T.E. (9).

d) Mesure des Pressions :

D'une façon générale, le terme "pressions" signifiera, dans ces essais, "pressions manométriques" et non "pressions absolues". La détermination de la répartition de pression le long du profil de la tuyère se fit au moyen de prises statiques reliées à l'intérieur de la chambre de la tuyère à des tubes de caoutchouc sortant de la tuyère à travers le corps de celle-ci au moyen de tubes de laiton rigides. Ces tubes de laiton étaient alors reliés par des tubes de caoutchouc souples à une batterie de manomètres (I0) différentiels à mercure. La pression dans la chambre de la tuyère était mesurée par un manomètre métallique, ou par un manomètre à mercure (5).

e) Mesures de traction :

La balance (6) était constituée de deux bras de levier horizontaux de chacun 2 m. de long; à un troisième bras de levier vertical était fixée la tuyère à essayer, de telle façon que l'axe de la tuyère soit, à quelques millimètres, situé à un mètre un point de rencontre géométrique des trois bras de levier de la balance. Le système des trois bras de levier reposait par l'intermédiaire de deux couteaux sur un socle rigide fixé au sol.

A l'arrêt, la balance était tarée de façon à ce que les deux bras de levier en prolongement l'un de l'autre soient effectivement horizontaux. En cours d'essais, la mesure de la traction s'effectuait par la mesure du couple produit par la balance; pour ce faire, on plaçait des poids sur des plateaux situés aux extrémités des bras de levier horizontaux de façon à amener effectivement ces bras de levier à l'horizontal. En fait, pour augmenter la précision et la rapidité des mesures, on fut amené à compléter ce système. A l'extrémité de l'un des bras horizontaux était pendue une chaîne dont l'extrémité libre pouvait être relevée et attachée à un point fixe indépendant de la balance par l'intermédiaire d'un moulinet; ce système permettait de charger d'une façon continue les plateaux de la balance.

f) Mesure du débit total :

Pour des raisons que nous expliquerons plus loin, le débit à la sortie du divergent n'a pu se faire qu'au tube de Pitot. Le tube de Pitot utilisé avait été construit et étalonné par le C.N.R.S. (Centre National de la Recherche Scientifique.)

La différence de pression était mesurée par un manomètre à eau.

during the tests (diaphragm pressure approx. 4.5 kg/cm² at 20°) could measure a flow of 50 to 500 grams per second. Then came another flow meter also with diaphragm, of the "HOI DEC" pyrometer type (11), which, in the given test conditions, could measure a flow of 250 to 1,300 grams per second.

c) Temperature measurements :

The temperature at the level of the flow meters was taken with special mercury thermometers (13).

The temperature at the level of the nozzle was measured by B.T.E. - C.T.E. thermocouples (9).

- d) The term "pressure", used in reference to these tests, means gauge pressure and not absolute pressure. The distribution of pressure along the profile of the nozzle was determined by means of static-pressure connections, connected inside the nozzle chamber to flexible rubber tubes, these being connected to rigid brass tubes passing out through the body of the nozzle, where they were again connected to rubber tubes leading to a set of mercury differential-pressure gauges (10). The pressure inside the nozzle chamber was measured by a metallic gauge or a mercury gauge (5).

e) Traction measurements :

The balance (6) was formed by two horizontal lever arms, each 2 meters long. The nozzle to be tested was attached to a third, vertical lever arm, in such a way that the axis of the nozzle was, to within a few millimeters, one meter from the geometrical point of intersection of the three lever arms of the balance. The element consisting of the three lever arms rested on two knife-edges attached to a rigid stand fixed to the ground.

The balance was adjusted so that when at rest the two lever arms lying in the same line were exactly horizontal. During the tests, the traction measurements were taken by measuring the couple produced by the balance. To do this, weights were placed on the plates at the extremities of the horizontal lever arms in order to bring them into the horizontal position. In order to increase the accuracy and rapidity of the measurements, we completed the system by hanging a chain from the end of one of the horizontal arms, which could be attached by means of a reel to a fixed point not connected with the balance. This system made possible a continuous adjustment of the level of the balance plates.

f) Measurement of the total flow.

For reasons which will be explained later, the discharge at the exit of the divergent could only be measured with a Pitot tube. The Pitot tube used was made and calibrated by the C.N.R.S. (National Center for Scientific Research).

The pressure difference was measured by a water gauge.

III. DISCUSSION ET PRECISION DES MESURES.

a) Incompatibilité entre la mesure de la traction et la mesure du débit total :

La chambre de la tuyère était alimentée en air primaire par un seul orifice, ce qui constitue une source d'irrégularités dans l'alimentation et dans l'écoulement.

En outre, il est évident que, par l'existence même de l'Effet COANDA, la vitesse d'écoulement le long de l'axe de la tuyère est plus faible qu'au voisinage des parois, d'où la nécessité pour une mesure précise du débit total par un système à diaphragme d'une longue canalisation cylindrique à la suite du divergent pour homogénéiser la veine. Un tel système, lourd, encombrant, ne permet pas alors de mesures simultanées de tractions.

La mesure de celles-ci nous paraissait plus intéressante que la mesure du débit total. En effet, théoriquement, la traction est égale au flux de quantité de mouvement sortant et une mesure précise de la vitesse à la sortie devrait permettre de calculer la traction; en fait, l'irrégularité de la tuyère fait que la quantité de mouvement n'est pas orientée suivant l'axe de la tuyère et la traction n'est plus égale, mais inférieure, au flux de quantité de mouvement sortant. On a donc été amené au système suivant : mesures directes des tractions au moyen de la balance sus-indiquée, mesures de la vitesse de sortie par sondages au Pitot en cinq points. On a tenté de régulariser un peu la veine en complétant la tuyère proprement dite par un divergent de réalisation quasi instantanée, formé de plaques de matière plastique lisse de poids négligeable et créant une perte de charge elle aussi négligeable.

Les vitesses de sortie indiquées dans les résultats des essais sont calculées d'après la moyenne des indications du Pitot et le débit total est calculé à partir de cette vitesse, de la section de sortie du divergent en matière plastique, en prenant pour densité de l'air celle correspondant à la température indiquée par le thermo-couple.

b) Précision de la mesure du débit primaire :

Le débitmètre BERI (I4) a une précision de l'ordre de plus ou moins 5 grammes. Les essais faits avec le débitmètre BERI correspondent à un débit primaire compris entre 50 et 500 grammes par seconde, et l'erreur relative est donc toujours comprise entre 1 et 10 %.

Le gyromètre "HOUDEC" (II) ne donne pas une précision supérieure à 15 grammes.

Ce débitmètre étant utilisé pour des débits supérieurs à 300 grammes/seconde, l'erreur relative est toujours inférieure à 5 %.

c) Précision de la mesure des températures :

La mesure des températures au niveau des débitmètres a été faite par thermomètres spéciaux au mercure (I3), gradués en 1/5ème de degré, à réponse rapide.

La précision était largement suffisante pour la mesure des débits.

La mesure des températures au niveau de la tuyère et à la sortie de la

III. DISCUSSION OF THE MEASUREMENTS AND THEIR PRECISION.

a) Discrepancy between the measurements of traction and total flow :

The nozzle chamber was fed with primary air from a single orifice, which constituted a source of irregularity in the air supply and the flow.

Besides, it is clear from the mere existence of the COANDA Effect that the flow along the nozzle axis is slower than along the walls, whence the necessity for accurate measurement of the total flow by a diaphragm system placed in a length of cylindrical tube extending the divergent, in order to render the flow homogeneous. Such a system, heavy and cumbersome, does not permit of simultaneous traction measurements. These measurements had a greater interest for us than those of the total flow. Theoretically, the traction is equal to the momentum flux emerging from the nozzle, and accurate measurement of the exit velocity should enable us to calculate the traction. In actual fact, however, the irregularity of the nozzle prevents the momentum from being directed along the axis of the nozzle and the traction is no longer equal to, but less than, the momentum emerging from the nozzle. We were thus led to adopt the following practice : direct measurement of the traction by the balance referred to above, and measurement of the exit velocity by soundings with the Pitot tube at five points. We tried to regularize the stream a little by extending the nozzle proper with a divergent, devised on the spur of the moment, formed of sheets of smooth plastic of negligible weight and creating only a negligible loss of energy in the air flow.

The exit velocities shown in the results of the tests are calculated according to the mean of the Pitot tube readings and the total flow is calculated from this velocity, at the exit section of the plastic divergent, taking the air density corresponding to the temperature shown by the thermocouple.

b) Accuracy of the measurements of primary flow.

The BERI flow meter (I4) reads accurately to within approximately 5 grams. The tests made with the BERI flow meter were for a primary flow of between 50 and 500 grams per second, so the error is always between 1 and 10 %.

The HOUDEC gyrometer (II) is only accurate to within 15 grams.

As this flow meter was used for flows above 300 grams per second, the error still remains less than 5 %.


c) Accuracy of the temperature measurements.

The temperature at the level of the flow meters was taken by special quick-reading mercury thermometers (I3), graduated in fifths of a degree.

Their precision was quite adequate for flow measurements.

The temperature at the level of the nozzle and at its exit was measured

tuyère était faite par thermocouples (9) fournis par le C.N.R.S. Le schéma de l'installation était le suivant :




La soudure froide des thermo-couples était maintenue à température constante; la soudure froide baignait dans du mercure placé dans un tube à essais plongeant dans de l'eau contenue dans une bouteille Thermos, elle-même entourée d'une caisse emplies de sciure de bois. Malgré les fortes amplitudes de température atmosphérique (jusqu'à 10° en une heure), la température de la soudure froide ne variait pas de plus d'un dixième de degré en une heure. Le courant circulant dans les thermo-couples était mesuré par un micro ampèremètre A.O.I.P. Un shunt à résistance variable étalonné permettait de faire varier la sensibilité du dixième de degré au degré.

D'une façon générale, cette installation était du type utilisable pour l'exploration de la couche limite thermique, mais étant très sensible aux écarts de température ambiante et n'ayant pas été isolée, la précision des mesures est de l'ordre de plus ou moins $2/10^{\text{èmes}}$ de degré.

Les vitesses auxquelles étaient soumises les soudures chaudes des thermo-couples ont permis de négliger l'influence de la forme de la soudure et les courants de convection du support de la soudure sur la température lue. L'un des thermo-couples était fixé à l'intérieur de la chambre de la tuyère, l'autre thermo-couple était placé à la sortie du divergent en plastique. Un système d'interrupteurs permettait des mesures quasi-instantanées de ces deux températures.

by thermocouples (9) supplied by the C.N.R.S. Their arrangement is shown in the following diagram :



The cold junctions of the thermocouples were maintained at constant temperature; the cold junction was immersed in mercury in a test tube standing in water contained in a thermos flask, the latter being in a wooden box filled with sawdust. In spite of considerable variations in the atmospheric temperature (up to 10°C in an hour), the temperature of the cold junction did not vary by more than a tenth of a degree in one hour. The current in the thermocouple circuit was measured by a micro-ammeter A.O.I.P. The sensibility could be varied from a tenth of a degree to one degree by means of a calibrated variable-resistance shunt.

In a general way, this system of thermocouples was of the type which can be used for exploration of the thermal boundary layer, but being very sensitive to changes in the surrounding temperature and not being insulated, the measurements were only accurate to within approximately $2/10$ ths of a degree centigrade.

The velocities to which the hot junctions of the thermocouples were exposed made it possible to disregard the influence on the temperature read of the shape of the junction and of the convection currents due to the junction holder. One of the thermocouples was fixed inside the chamber of the nozzle, the other was placed at the exit of the plastic divergent. A system of switches made it possible to take almost instantaneous measurements of these two temperatures.

d) Précision de la mesure du débit total :

La mesure du débit total est certainement la mesure la moins précise que nous ayons pu faire. On mesurait les vitesses autant que possible avec le Pitot et, quand le Pitot était insensible, avec un anémomètre. Le Pitot a été utilisé dès une vitesse de 5 m./sec., mais la répartition très complexe des vitesses à la sortie du divergent fait que la vitesse moyenne obtenue (par sondages en cinq points, rappelons-le), est peut-être assez loin de la réalité. Ceci peut conduire à des erreurs sensibles sur le débit total qui se répercuteront naturellement sur l'induction. Il est difficile de donner un ordre de grandeur de la précision; l'erreur relative est sans doute inférieure à 10 % pour les essais sur les tuyères à facettes où les vitesses mesurées étaient grandes. La précision ne doit pas dépasser 15 % pour les mesures sur les autres tuyères. Il en résulte qu'en valeur absolue les inductions sont données avec une variation du chiffre significatif de plus ou moins une unité.

Notons que le divergent en plastique réalisé était homothétique pour une famille de tuyères.

e) Précision de la mesure des Tractions :

La présence du joint tournant suivi d'une durite et la longueur des leviers de la balance faisaient qu'à vide la balance était sensible à la traction de 20 grammes, mais en cours d'essais la disymétrie de l'écoulement donnait naissance à un couple agissant sur les couteaux de la balance, diminuant la sensibilité de celle-ci, et on ne peut pas prétendre à une précision supérieure à 50 grammes.

f) Précision de la mesure des Pressions :

Répartition de pression sur le profil : Le diamètre des prises statiques était de l'ordre de 8/10èmes de millimètre. Sur une si faible distance le gradient de pression est cependant élevé puisque pour les tuyères à facettes la longueur d'une facette peut n'être que de quelques millimètres : la pression lue n'est donc qu'une pression moyenne. D'autre part, en cours d'essais, les niveaux de mercure dans les manomètres multiples pouvaient facilement osciller d'un centimètre (phénomène sans doute dû à la turbulence) : la précision des mesures des pressions sur le profil est de l'ordre de plus ou moins 5 mm. de mercure.

Pression dans la chambre de la tuyère : Pour les hautes pressions (supérieures à 1 Kg./cm²), on utilisa un manomètre métallique (5) qui n'avait pas été réétalonné (ce qui est sans importance pour des essais comparatifs), et on ne peut prétendre à une précision supérieure à 50 grammes par cm², ce qui devrait correspondre à une erreur relative inférieure à 5 %. Pour les basses pressions (inférieures au Kilogramme/cm².) le manomètre métallique était remplacé par un manomètre différentiel à mercure (étalonnage ci-joint), mais les erreurs de lecture dues à la parallaxe faisaient que la pression était obtenue à plus ou moins 5 grammes, ce qui assure une erreur relative toujours inférieure à 10 %.

IV. INTERPRETATION POSSIBLE DES RESULTATS :

- a) Les mesures les plus sûres réalisées sont les mesures de traction et de débit primaire, puis viennent les mesures de température qui, tout en étant sûres, restent difficiles à interpréter comme nous allons le voir. Viennent ensuite les mesures de répartition de pression sur le profil, de pression dans la chambre de la tuyère; enfin, les mesures les moins précises sont celles du débit total et de l'induction.

d) Accuracy of the measurements of total flow :

The least accurate of our measurements were certainly those of the total flow. We measured the velocities as far as possible with the Pitot tube, and when beyond the Pitot's range of readings, with an anemometer. The Pitot was used for velocities starting from 5 m./sec., but due to the very complex distribution of velocities at the exit of the divergent it is possible that the mean velocity obtained (by soundings at five points, as already stated) is perhaps rather far from correct. This could lead to appreciable errors in the total flow, which would naturally have repercussions on the induction measured. It is difficult to state the order of magnitude of the precision obtained; the relative error is no doubt under 10 % for the tests on the nozzles with facets, where the velocities measured were high. The precision probably does not exceed 15 % in the measurements made on the other nozzles. As a result the absolute value of the induction rates is given with a variation of the significant figure of plus or minus one unit.

It should be noted that the plastic divergent made was homothetic for one category of nozzles.

e) Accuracy of the traction measurements.

The presence of the turning joint followed by a durite tube, and the length of the arms of the balance gave the latter a sensitivity, when unloaded, of 20 grams, but in the course of the tests the dissymmetry of the flow gave rise to a couple acting on the knife-edges of the balance and reducing its sensitivity, so that we cannot assume accuracy to within less than 0,05 Kgm.

f) Accuracy of the pressure measurements.

Distribution of pressure along the profile : The diameter of the static pressure connections is of the order of 8/10ths of a millimeter. Over such a short distance the pressure gradient is still steep, since for nozzles with facets the length of a facet may be only a few millimeters : the pressure read is therefore only a mean pressure. In addition, during tests, the mercury level in the multiple gauges sometimes varied by as much as a centimeter (a phenomenon which was no doubt due to turbulence.) The pressure measurements along the profile are therefore accurate to within approximately 5 millimeters of mercury.

Pressure in the nozzle chamber : For high pressures (over 1 Kg./cm²), we used a metallic (Bourdon tube) gauge (5) which had not been recalibrated (which does not matter in comparative tests) and the accuracy of the measurements cannot be greater than to the nearest 50 grams per cm²., which would correspond to an error of 5 %. For low pressures (less than 1 Kg/cm²) the metallic gauge was replaced by a differential-pressure mercury gauge (see calibration table), but owing to the reading errors due to parallax the pressure noted was correct to within 5 grams, which means that the relative error was still below 10 %.

IV. POSSIBLE INTERPRETATION OF RESULTS :

- a) Of the measurements taken the most reliable are those of the traction and primary flow, then come the measurements of temperature which, though reliable, are difficult to interpret, as we shall see. Next come the measurements of pressure distribution along the profile, of the pressure in the nozzle chamber and finally the least accurate, namely, those of the total flow and the induction.

- b) La principale source d'erreurs provient de la difficulté que nous avons eue à établir un phénomène permanent. En effet, la consommation en air primaire était souvent supérieure à la capacité des compresseurs et il s'ensuivait une chute de pression sensible (jusqu'à 3 ou 4 Kgs.) dans les réservoirs extérieurs. La conséquence immédiate était une chute de température, une variation dans le débit primaire et, d'une façon générale, une variation du phénomène. C'est ce qui a conduit à faire des mesures aussi instantanées que possible des températures dans la tuyère et à la sortie de la tuyère, ces mesures n'étant intéressantes que dans la mesure où on les compare l'une à l'autre.
- c) D'une façon générale, on s'est efforcé de procéder à des mesures aussi instantanées et rapides que possible : la traction, la pression dans la chambre de la tuyère et le débit primaire étaient mesurés à peu près au même instant.
- d) Le rôle des conditions atmosphériques et surtout de la température ambiante est déterminant sur la nature des résultats, d'où la nécessité de mesures groupées dans un temps aussi court que possible.
- e) Les améliorations futures :

Les différentes familles de tuyères essayées ont permis une étude comparative intéressante qui a mis en évidence l'intérêt du phénomène. A la suite de ces travaux d'approche et selon les profils définitivement choisis, une étude future nécessiterait des moyens plus précis et une installation infiniment plus coûteuse.

En effet, une étude très poussée des phénomènes nécessiterait des essais durant plus de deux minutes pour que l'on soit certain d'atteindre l'état de régime. Pour cela, il faudrait une réserve d'air (sous 7 à 8 Kgs. de pression) de plus d'une tonne. Les vannes de réglage de pression devraient être automatiques. Le banc d'essais nécessiterait une gamme plus étendue de débitmètres; les manomètres devraient être du type à couteau miroir; les manomètres multiples devraient être réalisés avec des tubes parfaitement calibrés. Il faudrait aussi faire une utilisation systématique de la photo. Un autre système de mesure des tractions devrait aussi être réalisé (piezoélectrique), et il faudrait pouvoir mesurer aussi bien la traction, suivant l'axe de la tuyère, que les couples à axe vertical. Ceci nécessiterait sans doute soit de monter la balance pendulaire sur un plateau tournant, soit de remplacer la balance pendulaire par une balance aérodynamique à câbles du type utilisé pour les essais de maquette en soufflerie, etc

V. DEPOUILLEMENT ET PRESENTATION DES RESULTATS :

a) Débit primaire :

Les débitmètres avaient été étalonnés par les fabricants; les mesures nécessitaient des corrections de pression et de température.

b) Température :

On a procédé à l'étalonnage des thermo-couples pour la sensibilité la plus grande. Les essais de mesure de température du jet immédiatement à la sortie de la fente ont été faits; ils s'avèrent extrêmement délicats

- b) The chief source of errors arises from the difficulty we had in maintaining permanent conditions of the phenomenon being investigated. In point of fact, the consumption of primary air often exceeded the capacity of the compressors, which resulted in an appreciable fall in pressure (up to 3 or 4 kg.) in the external supply tanks. The immediate consequence was a fall in temperature, a variation in the primary flow and a general variation of the test conditions. This necessitated taking measurements as instantaneously as possible of the temperatures in the nozzle and at its exit, these two sets of measurements being of interest solely in their comparison with one another.
- c) In general, the measurements were made as rapidly and instantaneously as possible: the traction, the pressure in the nozzle chamber, and the primary flow were read at approximately the same instant.
- d) Atmospheric conditions and especially the temperature around the test bench affect the results, whence the necessity for grouping the measurements in a minimum of time.
- e) Future Improvements :

The tests on different categories of nozzles allowed us to make an interesting comparative study illustrating the importance of the phenomenon. Following this preliminary work and depending on the profiles finally chosen, a future study would demand more accurate equipment and a far more costly installation.

A thorough study of the phenomena would in fact require tests lasting more than two minutes in order to be sure of having a stable flow regime. This would require an air reserve (under 7 to 8 kg. pressure) of more than a ton. The pressure-regulating valves should be automatic. The test bench would require a wider range of flow meters; the pressure gauges should be of the knife-edge mirror type; the multiple pressure-gauges should be fitted with perfectly calibrated tubes. Systematic use should also be made of photography. Another measuring system (piezo-electric) would be adopted for the traction, and it should be possible to measure the couples about a vertical axis as well as the traction along the main axis of the nozzle. This would doubtless require mounting the swing balance on a turntable, or replacing it by a force-measurement balance with cables of the type used for testing models in wind-tunnels, etc...

V. SORTING AND PRESENTATION OF RESULTS.

- a) Primary flow :

The flow meters had been calibrated by the makers; the measurements necessitated corrections for pressure and temperature.

- b) Temperature :

The calibration of the thermocouples was carried out for maximum sensitivity. Measurements of the temperature of the jet were made right at the exit of the slot; they proved extremely delicate due to the slight

à cause de la faible épaisseur du jet et du gradient de pression élevé qui fait que la soudure du thermo-couple était plaquée contre la paroi.

c) Vitesse :

On a calculé la vitesse moyenne à la sortie du divergent en prenant la moyenne des lectures du Pitot et en calculant la vitesse par la Loi de Bernoulli en prenant pour densité celle correspondant à la température indiquée par les thermo-couples; de là on passe au débit total en conservant la même densité.

d) Traction :

Il a été procédé à l'étalonnage du couple dû au vrillage de la durite mise sous pression. En outre, il a été procédé à des essais comparatifs systématiques de traction pour déceler le rôle du divergent en plastique; pour cela, on procédait, dans des conditions identiques de pressions et d'ouvertures, à des mesures de traction pour la tuyère munie du divergent plastique et sans le divergent plastique.

e) Pression sur le profil :

Les mesures en millimètres de mercure ont été traduites en millimètres d'eau et reportées en ordonnées sur des courbes où l'abscisse est égale à l'abscisse curviligne le long du profil comptée à partir de la première prise de pression (courbe en développée).

f) A titre indicatif, notons qu'il a été procédé à plus de 650.essais; chaque essai comporte en moyenne 30 mesures, soit au total 19.500 mesures, et le dépouillement d'un seul essai comporte 35 opérations (corrections, moyennes, traduction en unités cohérentes, etc....), soit au total 22.750 opérations.

Les essais proprement dits ont nécessité en permanence la présence de six personnes.

La mise au point du banc d'essais (après montage) a demandé près de quinze jours.

Les dépouillements ont demandé plus d'un mois de travail, à cinq personnes.

g) Présentation des résultats :

Pour chaque tuyère essayée on trouvera successivement :

- un profil de lèvre fixe avec principales dimensions de la tuyère et tableau de correspondances des ouvertures au pas et ouvertures réelles.
- un tableau des mesures (sauf pression le long des profils et essais comparatifs de traction).
- la courbe du débit primaire en fonction de la pression dans la chambre de la tuyère (à iso-ouvertures au pas).
- les courbes de débit total en fonction de la pression dans la chambre de la tuyère (à iso-ouvertures au pas).

thickness of the jet and the steep pressure gradient which meant that the junction of the thermocouple was constantly being forced against the slot wall by the suction.

c) Velocity :

The mean velocity at the exit of the divergent was calculated by taking the mean of the Pitot readings and calculating the velocity according to Bernoulli's law, while taking as density that corresponding to the temperature shown by the thermocouples; whence the total flow is obtained retaining the same density.

d) Traction :

The couple resulting from the twisting of the durite tube under pressure was duly calibrated. Further systematic comparative tests of the traction were carried out to discover the effect of the plastic divergent. For this purpose measurements were taken, under identical conditions of pressure and opening, of the traction of the nozzle with and without the plastic divergent.

e) Pressure on the profile :

The measurements in millimeters of mercury were translated into millimeters of water and are shown as ordinates of the curves where the abscissae represent the curvilinear distances along the profile taken from the first pressure recording on the developed curve.

- f) As an indication of the work performed, it may be noted that over 650 tests were made, each involving an average of 30 measurements, or a total 19,500 measurements, and the sorting out, plotting and tabulation of the results of a single test includes 35 operations (corrections, averages, conversions into coherent units, etc...) which makes a total of 22,750 operations.

The actual tests necessitated the continuous presence of six people.

The preparation of the test bench (after erection) took nearly two weeks.

The sorting, tabulation and plotting of results required the work of 5 persons for over one month.

g) Presentation of results :

For each nozzle tested we have :

- a profile of the fixed lip with principal dimensions of the nozzle and a table showing the relations of opening by pitch to real opening.
- a table of measurements (except in the case of pressure along the profiles and comparative traction tests).
- the primary flow curve as function of the pressure in the nozzle chamber (at equal openings by pitch).
- the total flow curves as function of the pressure in the nozzle chamber (at equal openings by pitch)

- les courbes d'induction, en fonction de la pression dans la chambre de la tuyère (à iso-ouvertures au pas).
- les courbes de traction en fonction du débit primaire à iso-ouvertures pas et iso-pression dans la chambre de la tuyère.
- une série de courbes donnant la répartition des pressions sur les profils à iso-pression dans la chambre de la tuyère (autant de tableaux de courbes que d'ouvertures essayées).

Tous les résultats donnés sont des résultats nets, sauf pour les pressions dans la chambre de la tuyère inférieures à 1 Kg./cm²., pour lesquelles il faut tenir compte des courbes d'étalonnage.

Les commentaires de ces différents essais seront présentés à la suite de l'ensemble des courbes.

=====

- Fig. I. Schéma du banc d'essais.
- Fig. II. Vue d'ensemble du banc d'essais.
- Fig. III. Le réservoir tampon et les débitmètres.
- Fig. IV. Détail des débitmètres et des appareils donnant les conditions atmosphériques.
- Fig. V. Les manomètres multiples à mercure.
Détail de la balance (Joint tournant, durite et couteaux, etc ...)
- Fig. VI. Le micro-ampèremètre et les bouteilles Thermos.
- Fig. VII. La balance. Détail du dispositif à chaîne.
- Fig. VIII. Tuyère "302" en essais.
- Fig. IX. Etalonnage du manomètre différentiel à mercure.

- the induction curves as function of the pressure in the nozzle chamber (at equal openings by pitch).
- the traction curves as function of the primary flow at equal openings by pitch and equal pressure in the nozzle chamber.
- a series of curves giving the pressure distribution along the profiles at equal pressure in the nozzle chamber (as many curve sheets as openings tested).

All results given in this report are net-results, except for pressures in the nozzle chambers below 1 kg./cm²., where reference must be made to the calibration curves.

The comments on these different tests follow all the curves.

=====

- Fig. I. Diagram of test bench.
- Fig. II. General view of test bench.
- Fig. III. Buffer tank and flow meters.
- Fig. IV. Flow meters and apparatus for indicating atmospheric conditions.
- Fig. V. Set of mercury differential pressure gauges. Balance, showing turning joint, durite tube, knife-edges, etc ...
- Fig. VI. Micro-ammeter and thermos-flask.
- Fig. VII. Balance, showing chain device.
- Fig. VIII. "302" nozzle being tested.
- Fig. IX. Calibration table of mercury differential pressure gauge.

SCHEMA DU RANG D'ESSAIS

- I. Tube ϕ intérieur = 50 mm.
2. Prise de Mano.
3. Tube collecteur ϕ 100 mm.
4. Joint tournant.
5. Mano (pression dans la chambre de la Tuyère).
6. Balance pour essais Tuyères.
7. Thermomètre dans la Tuyère.
8. Tuyère à essayer.
9. Thermo-couples.
10. Manomètre à tubes multiples pour eau et mercure.
11. Gyromètre différentiel "Houdec".
12. Tube ϕ intérieur = 50 mm.
13. Thermomètres.
14. Débitmètre "Beri"
15. Réservoir, Capacité 2m3. environ.
16. Manomètre de 0 à 7 Kg./cm², avec robinet d'isolement, cadran 150 mm.
17. Vannes à grands volants (Réglage pression).
18. Petit réservoir.
19. Grand réservoir.
20. Bâti support.

DIAGRAM OF THE TEST BENCH

1. Tube, internal ϕ 50 mm.
2. Pressure gauge orifice.
3. Manifold ϕ 100 mm.
4. Turning joint.
5. Pressure gauge (pressure in nozzle chamber).
6. Balance for nozzle tests.
7. Thermometer inside nozzle.
8. Nozzle being tested.
9. Thermocouples.
10. Multiple-tube pressure gauge for water and mercury.
11. "Houdec" differential gyrometer.
12. Tube, internal ϕ 50 mm.
13. Thermometers.
14. "Beri" airflow meter.
15. Reservoir, approx. 2 m³ capacity.
16. Pressure gauge for 0 to 7 Kg./cm² with stop cock. Dial ϕ 150 mm.
17. Shutter controls (pressure regulation).
18. Small reservoir.
19. Large reservoir.
20. Supporting framework.

SFERI - COANDA

SCHEMA DU BANC D'ESSAIS

1. Tube ϕ intérieur = 50^{mm}

2. Prise de Mano

3. Tube collecteur ϕ 100^{mm}

4. Joint tournant

5. Mano (Pression dans la chambre de la Tuyère)

6. Balance pour essais tuyères

7. Thermomètre dans la tuyère

8. Tuyère à essayer

9. Thermo-couples

10. Manomètre à tubes multiples pour eau et mercure

15. R^eservoir. Capacité 2^m environ

11. Gyromètre différentiel "HOUDEC"

12. Tube ϕ intérieur = 50^{mm}

13. Thermomètres

14. Débitmètre "BERI"

2,200^m

16. Manomètre de 0 à 7^{kg}/cm²
avec robinet d'isolement
cadran ϕ 150^{mm}


P^t réservoir
18.

17. Vannes à grands volants
(Réglage pression)


G^t réservoir
19.


20. Bâti support


700






3














Etalonnage du manomètre différentiel à mercure donnant la pression dans la chambre de la tuyère.

Calibration of the mercury differential-pressure gauge giving the pressure in the nozzle chamber.

Pression lue Pressure read	Pression réelle Real pressure
1	1,030
0,9	0,925
0,8	0,817
0,7	0,713
0,6	0,615
0,5	0,512
0,4	0,411
0,3	0,309
0,2	0,205
0,1	0,105

Conditions de l'étalonnage :

Calibration conditions :

- Pression barométrique 763 mm. de mercure
- Humidité relative 48 %
- Température ambiante 16° C

- Barometric pressure 763 mm. of mercury
- Relative humidity 48 %
- Ambient temperature 16° C

RESULTATS

I. Famille de tuyères homothétiques à facettes :

Tuyère	I2
" "	I60
" "	22

II. Famille de tuyères homothétiques à profil arrondi :

Tuyère	I02 bis
" "	I62
" "	202
" "	302 bis

III. Famille de tuyères homothétiques à profil arrondi :

Tuyère	I04
" "	I64
" "	204
" "	304

IV. Famille de tuyères semblables à profil arrondi :

Tuyère	I02	{ commune à la deuxième famille.
" "	202	
" "	302	

RESULTS

I. Category of homothetic nozzles with facets :

Nozzle	I2
" "	I60
" "	22

II. Category of homothetic nozzles with rounded profile :

Nozzle	I02 b
" "	I62
" "	202
" "	302 b



III. Category of homothetic nozzles with rounded profile :

Nozzle	I04
" "	I64
" "	204
" "	304

IV. Category of similar nozzles with rounded profile :

Nozzle	I02	{ common to the second category.
" "	202	
" "	302	

SFERI-COANDA TUYERE 12



SFERI - COANDA NOZZLE 12 TUYERE

OPENING BY PITCH mm	0,2	0,2	0,2	0,2	0,5	0,5	0,5	0,5	0,5	0,8	0,8	0,8	0,8	0,8
PRESSURE NOZZLE CHAMBER kg/cm^2	1,5	2	3	4	1	1,5	2	3	4	1	1,5	2	3	4
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	16,5	16	16,5	16,5	16,7	16,7	17,1	16,7	16,7	14,8	14,9	15,3	15,9	16,1
TEMPERATURE EXIT $^{\circ}\text{C}$	18,3	18	17,9	17,7	17,6	17,3	17,2	17,5	17,2	15,4	15,4	15,5	14,8	12,2
VELOCITY EXIT m/s	26,7	37,7	38,8	44,8	37,7	45,3	52,7	61,6	70,2	47,6	57,9	64,6	75	82,1
PRIMARY AIR kg/s	0,042	0,058	0,079	0,110	0,089	0,126	0,147	0,200	0,252	0,152	0,189	0,226	0,320	0,394
TOTAL AIR kg/s	0,650	0,798	0,946	1,100	0,920	1,100	1,285	1,505	1,710	1,160	1,420	1,590	1,845	2,040
AIR INDUCTION RATIO	15,5	13,9	12	10	10,3	8,8	8,7	7,5	6,8	7,6	7,5	7	5,8	5,2
TRACTION kg	1,770	2,710	3,900	5,4	3,240	4,872	6,310	8,975	11	5,24	7,27	9,110	12,50	15,4
ATMOSPHERIC PRESSURE mm/Hg	765	765	765	766	765	765	765	765	765	769	769	769	769	769
ATMOSPHERIC TEMPERATURE $^{\circ}\text{C}$	18	18	18	18	17,5	17,5	17,5	17,5	18	15,5	15,5	15,5	15,5	15,5
ATMOSPHERIC HUMIDITY %	96	96,5	97	97	96	96	96	96	96	100	100	100	100	100


OPENING BY PITCH mm	1	1	1	1	1	1,5	1,5	1,5	1,5	2	2	2	3	3
PRESSURE NOZZLE CHAMBER kg/cm^2	0,5	1	1,5	2	3	4	1	1,5	2	0,5	1	1,5	0,5	1
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	14,7	14,5	14,5	14,2	14,7	1	15,1	14	14,3	14,7	13,4	13,7	14,8	13,4
TEMPERATURE EXIT $^{\circ}\text{C}$	15,9	15,9	15,6	15,3	14,3	1	16,2	16,1	15,4	16,5	16,1	15,5	16	16
VELOCITY EXIT m/s	41,6	54,7	63,6	73,5	80,8	87,6	50,5	67	76,7	53,8	73,2	84,5	64,8	86,6
PRIMARY AIR kg/s	0,137	0,189	0,239	0,282	0,304	0,476	0,215	0,283	0,346	0,268	0,367	0,483	0,415	0,560
TOTAL AIR kg/s	1,020	1,345	1,560	1,810	2,02	2,150	1,240	1,620	1,898	1,320	1,785	2,088	1,590	2,120
AIR INDUCTION RATIO	7,5	7,1	6,5	6,4	5,3	4,6	5,8	5,0	5,5	4,9	4,9	4,3	3,8	3,8
TRACTION kg	3,720	6,440	9,070	11,610	14,780	19,500	6,120	9,340	12,678	6,320	11,040	16,078	8,620	14,940
ATMOSPHERIC PRESSURE mm/Hg	769	769	769	769	769	769	770	769	769	770	770	770	770	770
ATMOSPHERIC TEMPERATURE $^{\circ}\text{C}$	16	16	16	15,5	15,5	15,5	16,5	16	16	16,9	16,9	17	17	17
ATMOSPHERIC HUMIDITY %	100	100	100	100	100	100	100	100	100	99	99	99	99	99

CCM 3/4 57

SFERI-COANDA

Tuyère 12

Débit en fonction de la pression
Primary Air flow as function of pressure



SFERI-COANDA

Tuyère 12

Débit total.
Total Air Flow

Débit total Kg/sec
Total Air flow.

20

15

10

5

2


3

4

Pression chambre Tuyère
Pressure in nozzle chamber
Kg/cm²
C.C.M. 3/4 57

LES PAPIERS CANSON France


LES PAPIERS CANSON France



SFERI-COANDA.

Tuyère 12.

Inductions




SFERI-COANDA.

Tuyère 12

Traction en fonction du débit primaire

Traction as function of primary air flow



SFERI-COANDA TUYERE 12


NOZZLE

OUVERTURE AU RAS
BAROMETRIC PRESSURE
AMBIENT TEMPERATURE
RELATIVE HUMIDITY

OUVERTURE AU RAS 0,5 mm
PRESSION BAROMETRIQUE 765 mm/Hg
TEMPERATURE AMBIANTE 17,5 °C
HUMIDITE RELATIVE 96 %

PRESSURE IN NOZZLE
CHAMBER AND PRIMARY
AIR

PRESSION	(———)	4 g/cm ² (0,252 g/s)
DANS LA	(- - - -)	3 g/cm ² (0,1995 g/s)
CHAMBRE	(- - - -)	2 g/cm ² (0,147 g/s)
DE LA	(- - - -)	1,5 g/cm ² (0,126 g/s)
TUYERE	(- - - -)	1 g/cm ² (0,089 g/s)
ET DEBIT	(- - - -)	
PRIMAIRE	(- - - -)	



DEVELOPED DIAGRAM COURBE EN DEVELOPPE
CCM 2/57

SFERI-COANDA

TUYERE 12

NOZZLE

OPENING BY ARCH

BAROMETRIC PRESSURE

AMBIENT TEMPERATURE

RELATIVE HUMIDITY

PRESSURE IN NOZZLE

CHAMBER AND PRIMARY

AIR

OUVERTURE AU PAS 0.2"

PRESSION BAROMETRIQUE 765 mm Hg

TEMPERATURE AMBIANTE 18° C

HUMIDITE RELATIVE 96 %

PRESSION

DANS LA

CHAMBRE


DE LA

TUYERE

ET DEBIT

PRIMAIRE

4 g/cm² (0.110 g/s)
 3 g/cm² (0.0785 g/s)
 2 g/cm² (0.0575 g/s)
 1.5 g/cm² (0.042 g/s)



DEVELOPED DIAGRAM COURBE EN DEVELOPPE
 C.C.M. 2/57

SFERI-COANDA TUYERE 12


NOZZLE

OPENING BY PITCH
BAROMETRIC PRESSURE
AMBIENT TEMPERATURE
RELATIVE HUMIDITY

OUVERTURE AU PAS 0,8°
PRESSION BAROMETRIQUE 760 mm Hg
TEMPERATURE AMBIANTE 15,5 °C
HUMIDITE RELATIVE 100 %

PRESSURE IN NOZZLE
(CHAMBER AND PRIMARY
AIR

PRESSION	4 kg/cm ² (0,394 kg/s)
CHAMBRE	3 kg/cm ² (0,320 kg/s)
DE LA	2 kg/cm ² (0,226 kg/s)
TUYERE	1,5 kg/cm ² (0,189 kg/s)
ET DEBIT	1 kg/cm ² (0,152 kg/s)
PRIMAIRE	



DEVELOPED DIAGRAM

COURBE EN DEVELOPPE

C.C.M. 2/57

SFERI-COANDA

TUYERE 12

NOZZLE

OPENING BY PITCH

BAROMETRIC PRESSURE

AMBIENT TEMPERATURE

RELATIVE HUMIDITY

OUVERTURE AU PAS 1°

PRESSION BAROMETRIQUE 769 mm Hg

TEMPERATURE AMBIANTE 15,8 °C

HUMIDITE RELATIVE 100 %

PRESSURE IN NOZZLE

CHAMBER AND PRIMARY

AIR

PRESSION

DANS LA

CHAMBRE


DE LA

TUYERE

ET DEBIT

PRIMAIRE

6 kg/cm ²	(0,475 kg/s)
3 kg/cm ²	(0,384 kg/s)
2 kg/cm ²	(0,2815 kg/s)
1,5 kg/cm ²	(0,2385 kg/s)
1 kg/cm ²	(0,189 kg/s)
0,5 kg/cm ²	(0,1365 kg/s)



DEVELOPED DIAGRAM - COURSE EN DEVELOPPE

C.C.M. 5/57

SFERI-COANDA

TUYERE 12

NOZZLE

OPENING BY PITCH

BAROMETRIC PRESSURE

AMBIENT TEMPERATURE

RELATIVE HUMIDITY

OUVERTURE AU PAS "S"

PRESSION BAROMETRIQUE 760 mm/Hg


TEMPERATURE AMBIANTE 16 °C

HUMIDITE RELATIVE 100 %

PRESSURE IN NOZZLE
CHAMBER AND PRIMARY
AIR

PRESSION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PRIMAIRE

— 2 kg/cm² (0.45 kg/s)
— 1.5 kg/cm² (0.34 kg/s)
— 1 kg/cm² (0.22 kg/s)
- - - 0.5 kg/cm² (0.11 kg/s)



DEVELOPEE

EN COURSE EN DEVELOPEE

CCM 3/57

NOZZLE


OPENING BY PITCH
BAROMETRIC PRESSURE
AMBIENT TEMPERATURE
RELATIVE HUMIDITY

PRESSURE IN NOZZLE
CHAMBER AND PRIMARY
AIR

SFERI-COANDA TUYERE 12

OUVERTURE AU RAS 2°
PRESSION BAROMETRIQUE 770 mm/Hg
TEMPERATURE AMBIANTE 16,3°C
HUMIDITE RELATIVE 99 %

PRESSION	(———)	1,5 g/cm ² (0,4325 g/s)
BOIS LA	(———)	1 g/cm ² (0,367 g/s)
CHAMBRE	(———)	0,5 g/cm ² (0,268 g/s)
DE LA	(———)	
TUYERE	(———)	
ET DE LA	(———)	
POUR	(———)	



DEVELOPED DIAGRAM - COURSE EN DEVELOPPE

C.E.M. 1/2 57

NOZZLE

OUVERTURE AU RAS 3"

BAROMETRIC PRESSURE

AMBIENT TEMPERATURE

RELATIVE HUMIDITY

PRESSURE IN NOZZLE
CHAMBER AND PRIMARY
AIR

SFERI-COANDA

TUYERE 12

OUVERTURE AU RAS 3"


PAISSE IN BAROMETRIQUE 770 mm/Hg

TEMPERATURE AMBIANTE 17°C

HUMIDITE RELATIVE 90 %

PRESSION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBY
NOZZLE

1" $\frac{g}{cm^2}$ / 0,560 $\frac{g}{s}$
0,5" $\frac{g}{cm^2}$ / 0,415 $\frac{g}{s}$



DEVELOPED DIAGRAM


COURBE EN DEVELOPPE

C.C.M. 57

SFERI-COANDA TUYERE 160

Fente $\phi 208 \text{ mm}$ Circ^m = 6537_m (Slot ϕ Circ^m)
 Lèvre mobile Pas du filetage = 17_m (Adjustable wall Thread pitch)
 Ouverture réelle = Ouverture au pas $\times \cos 15^\circ$ (Real open^g Open^g of pitch $\cos 15^\circ$)

Col de la Tuyère $\phi = 160 \text{ mm}$ Throat of the nozzle
 Sortie de la Tuyère $\phi = 300 \text{ mm}$ Exit of nozzle
 Divergent (Plastique) L = 1800_{mm} Divergent (Plastic)
 " " " " $\phi =$



NOZZLE
TUYÈRE

OPENING BY PITCH mm	0.2	0.2	0.2	0.2	0.4	0.4	0.4	0.6	0.6	0.6	0.6	0.8	0.8	0.8	0.8	0.8
PRESSURE NOZZLE CHAMBER kg/cm^2	1	2	3.1	4	1	2	3	4	1	2	3	4	0.5	1	1.5	2
TEMPERATURE NOZZLE CHAMBER °C	9.4	9.8	9.6	9.8	9	9.2	9.9	9.4	9.5	9.7	9.3	8	8.4	8.7	8.9	8.2
TEMPERATURE EXIT °C	9.5	11.2	11.1	10.3	10.7	10.9	10.8	10.3	10.2	10.5	10.9	11.1	10.3	11.5	11.2	11.7
VELOCITY EXIT m/s	11.7	18.5	25.8	28.2	21.1	29.2	34	42.7	25.2	37.3	42.4	46.4	23.1	30.2	36.4	40.8
PRIMARY AIR kg/s	=0.03	0.076	0.116	0.154	0.111	0.106	0.241	0.310	0.175	0.279	0.366	0.467	0.175	0.293	0.301	0.371
TOTAL AIR kg/s	1.010	1.730	2.420	2.640	1.975	2.710	3.190	4.010	2.360	3.500	3.980	4.340	2.160	2.830	3.390	3.925
AIR INDUCTION RATIO	=33.6	22.8	20.9	17.2	17.8	15	13.2	12.9	13.5	12.6	10.9	9.3	12.3	12.2	11.3	10.6
TRACTION kg	1,340	3,230	5,580	7,500	3,680	7,510	10,980	14,880	6,04	11,510	16,180	20,200	4,720	7,940	9,670	15,160
ATMOSPHERIC PRESSURE mm/Hg	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769
ATMOSPHERIC TEMPERATURE °C	8.6	9.2	9.7	9.8	10	10.1	10.2	10.4	10.2	10.2	10.4	10.8	10.8	11	11.4	11.8
ATMOSPHERIC HUMIDITY %	85	84	83	83	83	82	82	82	79	78	79	79	79	79	79	77

OPENING BY PITCH mm	1	1	1	1	1,5	1,5	1,5	2	2	2	3
PRESSURE NOZZLE CHAMBER kg/cm^2	0,5	1	1,5	2	0,5	1	1,5	0,5	1	1,5	0,5
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	0,2	9,4	9,6	9,7	9,6	9,7	9,1	0,0	0,0	7,2	7,6
TEMPERATURE EXIT $^{\circ}\text{C}$	11,9	12	13,3	13,3	13	12,2	12,7	13,4	13,7	14	13,6
VELOCITY EXIT m/s	26,1	33,3	30,5	45	31,4	40,8	49,2	30,2	45,2	51,4	43,4
PRIMARY AIR kg/s	0,223	0,302	0,376	0,480	0,341	0,477	0,601	0,435	0,508	0,770	0,720
TOTAL AIR kg/s	2,440	3,120	3,590	4,200	2,920	3,700	4,570	3,550	4,170	4,770	4,030
AIR INDUCTION RATIO	10,9	10,3	9,6	8,7	0,6	0,1	7,6	0,2	7,1	6,2	5,6
TRACTION kg	6,18	10,240	14,570	17,900	9,190	14,640	20,07	12,42	18,34	23,670	17,42
ATMOSPHERIC PRESSURE mm/Hg	769	769	769	769	769	769	769	769	769	769	769
ATMOSPHERIC TEMPERATURE $^{\circ}\text{C}$	12,1	12,2	12,5	12,8	12,0	12,1	12,1	13,0	14	14,3	14,3
ATMOSPHERIC HUMIDITY %	75	74	73	72	71	70	69	68	67	66	64

CCM 3/4 57

SFERI-COANDA

Tuyère 160

Débit en fonction de la pression
Primary Air flow as function of pressure

Débit primaire
Primary Air Flow
kg/sec

20

0.9

0.8

0.7

0.6

0.5

0.4

0.3

0.2

0.1

3/

Op. 9

2

1.5

1

0.8

0.6

0.4

0.2

Pression chambre Tuyère
Pressure in nozzle chamber
kg/cm²

2

3

LES PAPIERS CANSON France

G.C.M. 3/4 67


20

SFERI-COANDA

Tuyère 160

Débit total.
(Total Air flow)

Débit total Kg/sec
Total Air flow.



Pression chambre Tuyère
Pressure in nozzle chamber
Kg/cm²
C.C.M. 3/4 57

LES PAPIERS CANSON France

UNCLASSIFIED

**A
D 204074**

Armed Services Technical Information Agency

**ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA**


**FOR
MICRO-CARD
CONTROL ONLY**

2 OF 5


NOTICE: WHEN GOVERNMENT OR OTHER DRAWINGS, SPECIFICATIONS OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY RELATED GOVERNMENT PROCUREMENT OPERATION, THE U. S. GOVERNMENT THEREBY INCURS NO RESPONSIBILITY, NOR ANY OBLIGATION WHATSOEVER; AND THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED, FURNISHED, OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA IS NOT TO BE REGARDED BY IMPLICATION OR OTHERWISE AS IN ANY MANNER LICENSING THE HOLDER OR ANY OTHER PERSON OR CORPORATION, OR CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

UNCLASSIFIED

SFERI-COANDA Tuyère 160 Inductions



Pression chambre Tuyère
Pressure in nozzle chamber
Kg/cm²
C.C.M. 3/4 57




SFERI-COANDA

TUYERE 160

OUVERTURE AU PAS 3,2 mm
PRESSION BAROMETRIQUE 769 mm Hg
TEMPERATURE AMBIANTE 3,2 °C
HUMIDITE RELATIVE 84 %

PRESSION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PRIMAIRE

4 g/cm ²	/0,154 g/s/
3 g/cm ²	/0,116 g/s/
2 g/cm ²	/0,076 g/s/
1 g/cm ²	<0,053 g/s/



COURBE EN DIVERGENCE

CCM 2/87

SFERI-COANDA TUYERE 160


OUVERTURE AU PAS 0,4"

PRESSION BAROMETRIQUE 753 mm Hg

TEMPERATURE AMBIANTE 10,8 °C

HUMIDITE RELATIVE 82 %

PRESSION	4 g/cm ²	0,310 g/s
DANS LA	3 g/cm ²	0,241 g/s
CHAMBRE	2 g/cm ²	0,180 g/s
DE LA	1 g/cm ²	0,111 g/s
TUYERE		
ET DEBIT		
PRESSION		



COURBE EN DEVELOPPE

22/2/87

SFERI-COANDA

TUYERE 160


OUVERTURE AU PAS 0.1"

PRESSION BAROMETRIQUE 753 mmHg

TEMPERATURE AMBIANTE 10.5°C

HUMIDITE RELATIVE 75%

PRESSION ——— 4 g/cm² (0.467 g/s)
 ANGLE ——— 3 g/cm² (0.366 g/s)
 TUBERIE ——— 2 g/cm² (0.278 g/s)
 DE LA ——— 1 g/cm² (0.175 g/s)
 TUYERE
 ET BENT
 FORMARE



COINCE EN DEVELOPPE

11-1/2 57

SFERI-CO.ANDA TUYERE 160


OUVERTURE AU PAS 0.2"

PRESSON BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 11.6° C

HUMIDITE RELATIVE 79%

PRESSON	3 g/cm ²	(0.508 g/s)
DANS LA	2 g/cm ²	(0.371 g/s)
CHAMBRE	1.5 g/cm ²	(0.301 g/s)
DE LA	1 g/cm ²	(0.233 g/s)
TUYERE	0.5 g/cm ²	(0.175 g/s)
ET DEBIT		
PROCHAINE		



COURBE EN DEVELOPPE

ccm 1/8 87

STERI-COANDA TUYERE 160

OUVERTURE AU PAS 1"

PRESSION BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 22.5 °C

HUMIDITE RELATIVE 73.5 %


PROFIL
BAMBA
CHAMBR
DE LA
TUYERE
ET DEBIT
PREPARE

2 g/cm² / 0.480 g/s

1.5 g/cm² / 0.376 g/s

1 g/cm² / 0.302 g/s

0.5 g/cm² / 0.223 g/s



COURBE EN DEVELOPPE

cm 1/57

SFERI-COANDA

TUYERE 160


OUVERTURE AU PAS 15°

PRESSIION BAROMETRIQUE 763 mmHg

TEMPERATURE AMBIANTE 12.5 °C

HUMIDITE RELATIVE 70 %

PRESSIION	15 g/cm ² / 0.601 g/s
CHAMBRE	1 g/cm ² / 0.470 g/s
DE LA	0.5 g/cm ² / 0.341 g/s
TUYERE	
ET DEBIT	
PARIARI	



COANDA EN DEVELOPPE

ccm 2/87

SFERI-COANDA

TUYERE 160


OUVERTURE AU RAS 2"

PRESSION BAROMETRIQUE 769 mm/Hg

TEMPERATURE AMBIANTE 18°C

HUMIDITE RELATIVE 67%

PRESSION	1,5 kg/cm ² (0,170 kg/s)
DANS LA	1 kg/cm ² (0,508 kg/s)
CHAMBRE	0,5 kg/cm ² (0,435 kg/s)
DE LA	
TUYERE	
ET DEBIT	
POUR LA	




COINCE EN DEVELOPPE

CC-8, 57

SFERI-COANDA TUYERE 160

OUVERTURE AU BAS 3 mm
PRESSION BAROMETRIQUE 763 mm Hg
TEMPERATURE AMBIANTE 19.3 °C
HUMIDITE RELATIVE 64 %


PRESSION 0.5 g/cm² (0.720 g/s)
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PREPARE



SFERI - COANDA TUYERE 22

Fente $\phi 260 \text{ mm}$ Circ^o = 816 mm (Slot ϕ Circ^o)
 Lèvre mobile Pas du filetage = 1.5 mm (Adjustable wall Thread pitch)
 Ouverture réelle = Ouverture au pas $\times \cos 15^\circ$ (Real open^g Open^g of pitch. Cos^o)

Col de la Tuyère $\phi = 200 \text{ mm}$ Throat of the nozzle
 Sortie de la Tuyère $\phi = 292 \text{ mm}$ Exit of nozzle
 Divergent (Plastique) $L = 2260 \text{ mm}$ Divergent (Plastic)
 " " " " $\phi = 320 \text{ mm}$



NOZZLE
TUYÈRE

OPENING BY PITCH mm	0,1	0,1	0,1	0,1	0,1	0,2	0,2	0,2	0,2	0,2	0,3	0,3	0,3	0,3	0,3	0,6	0,6	0,6
PRESSURE NOZZLE CHAMBER kg/cm^2	1	2	3	4	4	1	2	3	4	4	1	2	3	4	4	0,5	1	3
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	10,7	10,7	11	11	11	11,2	11,3	11,3	11,3	11,3	11,3	11,5	11,5	12,2	20,4	20,4	20,4	20,5
TEMPERATURE EXIT $^{\circ}\text{C}$	10,8	11,3	11,7	11,9	11,9	12,3	12,5	12,3	12,2	12,2	12,0	12,5	13	13,1	20,3	20,3	20,3	20,3
VELOCITY EXIT m/s	11,5	17,3	20	23	23	16,3	22,4	20,0	31,2	31,2	19,7	27,2	33,7	37,5	21,2	30,2	34,5	41,5
PRIMARY AIR kg/s	=0,03	0,081	0,113	0,153	0,153	0,084	0,139	0,106	0,234	0,234	0,121	0,192	0,250	0,317	0,116	0,100	0,230	0,291
TOTAL AIR kg/s	1,150	1,720	1,905	2,200	2,200	1,625	2,220	2,060	3,110	3,110	1,950	2,700	3,350	3,720	2,05	2,520	3,320	4
AIR INDUCTION RATIO	=38	21,3	17,5	14,9	14,9	19,3	16	15,4	13,3	13,3	16,1	14,1	13	11,7	17,6	16,2	19,95	19,75
TRACTION kg	1,340	3,01	4,30	5,6	5,6	2,49	5,31	7,30	9,4	9,4	3,04	7,21	10,50	14,0	4,34	8,01	11,40	15,8
ATMOSPHERIC PRESSURE mm/Hg	764	764	764	764	764	764	764	764	764	764	764	764	764	764	767	767	767	767
ATMOSPHERIC TEMPERATURE $^{\circ}\text{C}$	12	11,8	11,6	11,4	11,4	12,8	12,6	12,4	12,2	12,2	13,6	19,4	13,2	13	21,5	21,5	21,2	21,4
ATMOSPHERIC HUMIDITY %	73	74	74	74	74	70	70	71	73	73	68	69	69	69	80	80	80	81


OPENING BY PITCH mm	0.6	0.9	0.9	0.9	0.9	0.9	1.2	1.2	1.2	1.2	1.2	1.5	1.5	1.5	1.5	2	2	2	2	3
PRESSURE NOZZLE CHAMBER kg/cm ²	4	0.3	0.5	1	2	3	0.1	0.3	0.5	1	2	0.1	0.3	0.5	1	0.1	0.3	0.5	0.5	0.1
TEMPERATURE NOZZLE CHAMBER °C	—	20.3	20.2	—	18.8	19.4	20.1	20.2	19.9	19.4	—	20.3	19.5	19.8	18.9	19.2	19.3	19.3	19.3	19
TEMPERATURE EXIT °C	—	19.5	20.4	—	20.6	21.7	19.9	20.3	20.9	20.7	—	19.8	20.4	20.4	20.1	21	20.4	20.3	20.3	20
VELOCITY EXIT m/s	56.2	22.3	29.3	40	51.7	60	14.9	26	32.6	44	66.5	10.1	29.7	36.2	44.8	21	39.2	42.7	42.7	25.9
PRIMARY AIR kg/s	0.576	0.194	0.254	0.333	0.518	0.723	0.153	0.265	0.339	0.430	1.07	0.196	0.323	0.409	0.563	0.270	0.450	0.500	0.500	0.170
TOTAL AIR kg/s	5.42	2.14	2.82	3.06	5	5.77	1.44	2.585	3.12	4.23	6.4	1.74	2.06	3.48	4.7	2.03	3.2	4.12	4.12	1.5
AIR INDUCTION RATIO	9.4	11.1	11.1	11.6	9.6	8	9.4	9.5	9.3	9.8	6	8.9	8.3	8.5	8.4	7.5	7.1	6.9	6.9	5.9
TRACTION kg	20.04	4.51	7.42	13.435	29.81	32.15	2	6.21	7.82	16.74	=39.1	2.8	7.81	12.03	20.04	3.7	10.51	15.92	15.92	5.0
ATMOSPHERIC PRESSURE mm/Hg	767	767	767	767	767	767	767	767	767	767	767	767	767	767	767	767	767	767	767	767
ATMOSPHERIC TEMPERATURE °C	21.4	20.7	21.2	21.2	21.7	21.8	21.3	21.2	21.2	21.2	21.2	21.2	21.2	21.2	21.2	21.2	21.2	21.2	21.2	21.1
ATMOSPHERIC HUMIDITY %	80	75	75	75	70	80	76	76	75	70	70	78	78	78	78	70	70	70	70	76

CCM 3/4 57

SFERI-COANDA

Tuyère 22

Débit en fonction de la pression
Primary Air flow as function of pressure



Pression chambre Tuyère
Pressure in nozzle chamber
kg/cm²


C.C.M 3/4 57 20

LES PAPIERS CANSON France

SFERI-COANDA

Tuyère 22.


Débit total.
Total Air flow




Pression chambre Tuyère
Pressure in nozzle chamber
kg/cm²
C.C.M. 3/4 57

LES PAPIERS CANSON FRANCE

SFERI-COANDA.
Tuyère 22
Inductions.





SFERI-COANDA

TUYÈRE 22


OUVERTURE AU BAS 0,1 mm

PRESSION BAROMETRIQUE 760 mm/Hg

TEMPERATURE AMBIANTE 11,7°C

HUMIDITE RELATIVE 74%

PRESSION	4 kg/cm ²	(0,153 kg/s)
DANS LA	3 kg/cm ²	(0,113 kg/s)
CHAMBRE	2 kg/cm ²	(0,081 kg/s)
DE LA	1 kg/cm ²	(< 0,053 kg/s)
TUYÈRE		
ET DÉBIT		
PRIMAIRE		




COURBE EN DEVELOPPE

cm 1/3 57

SFERI-COANDA TUYERE 22

OUVERTURE AU PAS 0,2 mm
PRESSION BAROMETRIQUE 760 mm Hg
TEMPERATURE AMBIANTE 12,5 °C
HUMIDITE RELATIVE 71 %



COURBE EN DEVELOPPE

CCM 57

SFERI-COANDA


TUYERE 22

OUVERTURE AU RAS 0,3°

PRESSION BAROMETRIQUE 760 mm/Hg

TEMPERATURE AMBIANTE 19,3 °C

HUMIDITE RELATIVE 69 %



COURBE EN DEVELOPPE


cc 2/87

SFERI-COANDA TUYERE 22

OUVERTURE AU PAS 0.3"
PRESSION BAROMETRIQUE 767 mm Hg
TEMPERATURE AMBIANTE 21.5 °C
HUMIDITE RELATIVE 80%

PRESSION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PRIMAIRE

4 g/cm² (0.291 g/s)
3 g/cm² (0.238 g/s)
2 g/cm² (0.190 g/s)
1 g/cm² (0.116 g/s)



COURBE EN DEVELOPPE

ccm 1/57

SFERI-COANDA

TUYERE 22


OUVERTURE AU PAS 0.6"

PRESSION BAROMETRIQUE 767 mm/Hg

TEMPERATURE AMBIANTE 21.6°C

HUMIDITE RELATIVE 80%

PRESSION	6 g/cm ²	(0.576 g/s)
CHAMBER	3 g/cm ²	(0.406 g/s)
DE LA	2 g/cm ²	(0.313 g/s)
TUYERE	1 g/cm ²	(0.199 g/s)
ET DEBIT	0.5 g/cm ²	(0.168 g/s)
PREMIERE		



COURBE EN DEVELOPPE

cc-1, 57

SFERI-COANDA

TUYERE 22

OUVERTURE AU BAS 0,3 mm

PRESSION BAROMETRIQUE 767 mm Hg


TEMPERATURE AMBIANTE 21,6 °C

HUMIDITE RELATIVE 78 %

PRESSION	3 g/cm ²	(0,723 g/s)
DE LA	2 g/cm ²	(0,510 g/s)
CHAMBRE	1 g/cm ²	(0,316 g/s)
DE LA	0,5 g/cm ²	(0,254 g/s)
TUYERE	0,3 g/cm ²	(0,196 g/s)

ET DEBIT

PRELATS



COURBE EN DEVELOPPE

CEM 2/57

SFERI-COANDA

TUYERE 22


OUVERTURE AU PAS 12°

PRESSION BAROMETRIQUE 767 mm Hg

TEMPERATURE AMBIANTE 21.2°C

HUMIDITE RELATIVE 77%

PRESSION	2 g/cm ²	(1.070 g/s)
DANS LA	1 g/cm ²	(0.430 g/s)
CHAMBRE	0.5 g/cm ²	(0.339 g/s)
DE LA	0.3 g/cm ²	(0.265 g/s)
TUYERE	0.1 g/cm ²	(0.153 g/s)
ET DEBIT		
RECHER		




COURBE EN DEVELOPPE

ccm 57

SFERI-COANDA TUYERE 22

OUVERTURE AU PAS 1,5 mm
PRESSION BAROMETRIQUE 767 mm Hg
TEMPERATURE AMBIANTE 21,2 °C
HUMIDITE RELATIVE 78 %



SFERI-COANDA

TUYERE 22

OUVERTURE AU PAS 2°


PRESSIION BAROMETRIQUE 1013 mm Hg

TEMPERATURE AMBIANTE 21.2°C

HUMIDITE RELATIVE 70 %

PRESSIION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PREMIERE


0.5 g/cm² (0.598 g/s)
0.5 g/cm² (0.450 g/s)
0.1 g/cm² (0.270 g/s)





OUVERTURE AU PAS 3--
PRESSION BAROMETRIQUE 767 mm/Hg
TEMPERATURE AMBIANTE 21.3°C
HUMIDITE RELATIVE 76%

OUVERTURE AU PAS 3--
PRESSION BAROMETRIQUE 767 mm/Hg
TEMPERATURE AMBIANTE 21.3°C
HUMIDITE RELATIVE 76%

PREJUDICIELLE
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PREJUDICIEL



SFERI-COANDA TUYERE 102 Bis



SFERI - COANDA NOZZLE 102 BIS TUYERE


OPENING BY PITCH mm	1	1	1	1	1	1	1	1	3	3	3	3	3	3
PRESSURE NOZZLE CHAMBER kg/cm ²	0,1	0,2	0,4	0,6	0,8	1	1,250		0,05	0,1	0,2	0,4	0,6	0,8
TEMPERATURE NOZZLE CHAMBER °C	13,1	16,1	16,9	16,6	17,5	18,1	17,8		13,7	13,7	17	17,1	17,1	11,4
TEMPERATURE EXIT °C	15,9	18,2	20,1	19,3	17,4	17,4	18,4		15,8	16	17,5	18,2	13,5	13,5
VELOCITY EXIT m/s	12,4	15,5	21	25	29,8	33,3	35,6		13,7	20,1	28,2	37,9	42,7	43
PRIMARY AIR kg/s	-0,025	-0,05	0,071	0,100	0,117	0,120	0,140		0,079	0,115	0,173	0,241	0,276	0,326
TOTAL AIR kg/s	0,525	0,636	0,870	1,045	1,255	1,400	1,490		0,576	0,850	1,100	1,595	1,800	1,830
AIR INDUCTION RATIO	~21	12,7	12,3	10,4	10,7	10,9	10,6		7,3	7,4	6,8	6,6	6,5	5,6
TRACTION kg	0,500	1,100	2,110	2,915	3,925	4,435	5,050		0,800	1,500	4,900	5,210	6,515	7,325
ATMOSPHERIC PRESSURE mm/Hg	767	769	769	769	769	769	769		767	767	769	769	767	767
ATMOSPHERIC TEMPERATURE °C	16	18,6	19	19	19	19	19		16,4	16,3	18,8	18,4	13,8	13,8
ATMOSPHERIC HUMIDITY %	97	83	84	84	82	82	82		96	96	82	82	97	98

OPENING BY PITCH mm	5	5	5	5	5	5	7	7	7	7	7	9	9	9
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,2	0,3	0,4		0,05	0,1	0,150	0,2	0,3	0,05	0,1	0,150
TEMPERATURE NOZZLE CHAMBER °C	11,3	11,1	11,7	11,9	9,1		11,4	11,1	10,2	7,9	7,7	11,7	9,4	8,4
TEMPERATURE EXIT °C	13,4	13,4	12,4	11,8	13		12,8	13,2	13,6	13,6	13,6	14,5	14	14
VELOCITY EXIT m/s	18,4	25,8	34,2	40,8	44,5		20,9	27,6	34,3	38,6	42,5	19,4	29	33
PRIMARY AIR kg/s	0,165	0,224	0,315	0,373	0,430		0,260	0,338	0,394	0,440	0,485	0,285	0,374	0,482
TOTAL AIR kg/s	0,785	1,110	1,478	1,758	1,910		0,895	1,188	1,460	1,650	1,820	0,835	1,236	1,400
AIR INDUCTION RATIO	4,8	4,9	4,7	4,7	4,4		3,4	3,5	3,7	3,8	3,8	2,9	3,3	2,9
TRACTION kg	1,4	2,4	4,7	6,105	6,91		1,7	3,2	4,2	5,4	6,805	1,9	3,2	4,2
ATMOSPHERIC PRESSURE mm/Hg	767	767	767	767	767		767	767	767	767	767	767	767	767
ATMOSPHERIC TEMPERATURE °C	14,1	14	13,8	13,9	13,9		14,1	14,4	14,7	15	15,4	15,6	15,6	15,7
ATMOSPHERIC HUMIDITY %	98	98	98	98	98		98	99	99	99	99	98	98	98


SFERICOANDA

Tuyère 102^o

Debit en fonction de la pression
Primary air flow as function of pressure




SFERI-COANDA
 Tuyère 102.^B
 Débit total
 Total Air flow



SFERI-COANDA.

Tuyère 102.^B


Inductions



SFERI-COANDA.

Tuyère 102.B

Traction en fonction du débit primaire
Traction as function of pressure air flow



SFERI-COANDA

TUYERE 102


OUVERTURE AU RAS

PRESSION BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 19°C

HUMIDITE RELATIVE 82%

PRESSION	1.28 kg/cm ² (0.188 kg/cm ²)
DANS LA	1.5 kg/cm ² (0.128 kg/cm ²)
CANON	0.8 kg/cm ² (0.117 kg/cm ²)
DE LA	0.6 kg/cm ² (0.100 kg/cm ²)
TUYERE	0.4 kg/cm ² (0.071 kg/cm ²)
ET	0.2 kg/cm ² (0.042 kg/cm ²)
DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE

cm 1/2

SFERI-COANDA

TUYERE 102 ^{mm}


OUVERTURE AU BAS 3 ^{mm}

PRESSION BAROMETRIQUE 767 ^{mm} Hg

TEMPERATURE AMBIANTE 16,3 °C

HUMIDITE RELATIVE 96 %

PRESSION (——— 0,1 ^{kg}/cm² / 0,115 ^{kg}/s)
 DANS LA (——— 0,05 ^{kg}/cm² / 0,079 ^{kg}/s)
 CHAMBRE (- - - - -)
 DE LA (- - - - -)
 TUYERE (———)
 ET DEBIT (- - - - -)
 PRIMAIRE (- - - - -)



COURBE EN DEVELOPPE

CCM 1/2 87

SFERI-COANDA

TUYERE 102^{mm}


OUVERTURE AU BAS 3"

PRESSION BAROMETRIQUE 769^{mm} Hg

TEMPERATURE AMBIANTE 19.7°C

HUMIDITE RELATIVE 92%

PRESSION	—	0.6 g/cm ³ (0.276 g/s)
DANS LA	- - -	0.8 g/cm ³ (0.281 g/s)
CHAMBRE	- - -	0.3 g/cm ³ (0.173 g/s)
DE LA		
TUYERE		
ET DEBIT		
PRIMAIRE		



COURBE EN DEVELOPPE

CCM 1/2 87

SFERI-COANDA

TUYERE 108°


OUVERTURE AU PAS 1°

PRESSION BAROMETRIQUE 767 mm Hg

TEMPERATURE AMBIANTE 13.0°C

HUMIDITE RELATIVE 57%

PRESSION	—	4.9 g/m ³ / 0.572 g/s
DANS LA	- - -	0.8 g/m ³ / 0.926 g/s
CHAMBRE	- - -	
DE LA	- - -	
TUYERE	- - -	
ET DEBIT	- - -	
PRIMAIRE	- - -	



COURBE EN DEVELOPPE

CCM 6/87

SFERI-COANDA

TUYERE 102°


OUVERTURE AU RAS 5°

PRESSION BAROMETRIQUE 767 mm Hg

TEMPERATURE AMBIANTE 19°C

HUMIDITE RELATIVE 30%

PRESSION	0.6 g/cm ² / 0.250 g/s
DANS LA	0.5 g/cm ² / 0.275 g/s
CHAMBRE	0.2 g/cm ² / 0.345 g/s
DE LA	0.1 g/cm ² / 0.270 g/s
TUYERE	0.05 g/cm ² / 0.465 g/s
ET DANS	
PRIMAIRE	



COURBE EN DEVELOPPE

CC-1, 87

SFERI-COANDA

TUYERE 102 mm


OUVERTURE AU BAS 7 mm

PRESSION BAROMETRIQUE 767 mm/Hg

TEMPERATURE AMBIANTE 14,9°C

HUMIDITE RELATIVE 99%

PRESSION	—	0,300 g/cm ³ (0,085 g/s)
DANS LA	- - -	0,200 g/cm ³ (0,060 g/s)
CHAMBRE	- - -	0,100 g/cm ³ (0,030 g/s)
DE LA	- - -	0,400 g/cm ³ (0,330 g/s)
TUYERE	- - -	0,050 g/cm ³ (0,060 g/s)
ET DÉBIT	- - -	
PRIMAIRE	- - -	



SFERI-COANDA

TUYERE 102 $\frac{1}{2}$


OUVERTURE AU RAS 3"

PRESSION BAROMETRIQUE 767 mm Hg

TEMPERATURE AMBIANTE 15.6 °C

HUMIDITE RELATIVE 99 %

PRESSION	0.150 $\frac{1}{2}$ / 0.482 $\frac{1}{2}$
DE LA	0.100 $\frac{1}{2}$ / 0.374 $\frac{1}{2}$
CHAMBRE	0.050 $\frac{1}{2}$ / 0.205 $\frac{1}{2}$
DE LA	
TUYERE	
ET D'ENTRÉE	
PRIMAIRE	



COURBE EN DEVELOPPE

SFERI-COANDA

TUYÈRE 162

Fente ϕ 2 1/4" Circ. 672 % (Slot ϕ circ.¹⁰)
 Lèvre mobile Pas du filetage 1 7/8" (Adjustable well Thread pitch)
 Ouvertures recollées (Voir tableau) (Real opening see table)

	(Throat of the nozzle)
Col de la Tuyere	$\phi = 160 \text{ mm}$
Sortie de la Tuyere	$\phi = 300 \text{ mm}$
Divergent (Plastique)	$L = 1600 \text{ mm}$
" " " "	$\phi = 310 \text{ mm}$


Opportunités réelles

$\frac{m}{m}$	$\frac{m}{m}$
0.25	0.25
0.75	0.75
15	15
225	225
3	3
45	45
6	6
9	9

1
 4 Fanta
 = 2147m

Läura
mobile

Lèvre fine



SFERI - COANDA NOZZLE TUYERE 162


OPENING BY PITCH mm	0,25	0,25	0,25	0,25	0,25	0,25	0,25	0,25	0,25	0,25	0,25	0,75	0,75	0,75	0,75	0,75	0,75	1,5	1,5	1,5	1,5
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,5	0,5	0,5	0,5	0,05	0,1	0,15	0,2	0,25	0,3	0,05	0,1	0,15	0,2
TEMPERATURE NOZZLE CHAMBER °C	12,6	12,7	13	12,7	13,3	13,5	13,4	13	12,9	14,1	12,9	14,5	14,5	14,6	14,7	13,9	13,3	15,3	15,4	15,9	15,7
TEMPERATURE EXIT °C	14	14,2	14,7	15	15	15,6	15,7	15,9	15,6	15,7	16	15,8	16,3	17,1	17,2	17,7	17,7	16,6	16,9	17,1	17,4
VELOCITY EXIT m/s	10	15,2	18	20,7	24,6	25,6	30,7	35,5	11,3	16,1	18	24	26,6	30,3	34	38,4	38,4	12,5	18	22,8	25,4
PRIMARY AIR kg/s	0,086	0,139	0,173	0,195	0,230	0,257	0,299	0,341	0,110	0,163	0,199	0,236	0,262	0,294	0,352	0,406	0,406	0,142	0,200	0,247	0,289
TOTAL AIR kg/s	0,930	1,420	1,660	1,905	2,280	2,360	2,830	3,170	1,045	1,490	1,650	2,200	2,450	2,760	3,100	3,500	3,500	1,145	1,645	2,100	2,170
AIR INDUCTION RATIO	10,8	10,2	9,6	9,8	9,9	9,2	9,5	9,6	9,5	9,1	8,3	9,3	9,3	9,4	8,8	8,6	8,6	8,1	8,2	8,4	8
TRACTION kg	0,980	2	3,1	4,1	5,205	6,305	8,410	10,335	1,1	2,3	3,5	4,7	5,905	7,285	9,518	12,043	12,043	1,400	2,000	4,300	5,820
ATMOSPHERIC PRESSURE mm/Hg	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775
ATMOSPHERIC TEMPERATURE °C	14,8	15,1	15,4	15,7	16	16,4	16,6	16,7	17,1	17,2	17,3	17,4	17,4	17,5	17,7	17,6	17,6	17,8	18	18,1	18,2
ATMOSPHERIC HUMIDITY %	83	82	82	81	81	80	79	78	77	77	77	77	77	76	76	76	76	75	74	73	72

OPENING BY PITCH mm	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5	3	3	3	3	3	3	4,5	4,5	4,5	4,5
PRESSURE NOZZLE CHAMBER kg/cm ²	0,25	0,3	0,35	0,4	0,4	0,4	0,4	0,4	0,05	0,1	0,15	0,2	0,25	0,3	0,35	0,4	0,4	0,05	0,1	0,15	0,2
TEMPERATURE NOZZLE CHAMBER °C	15,7	15,8	15	15,1	15,1	17	16,8	16	17	17	16,8	16	16,5	16,4	16,2	16,4	16,4	10,8	10,8	10,5	10,5
TEMPERATURE EXIT °C	17,2	17,8	18	18,5	18,5	17,5	18,1	18,5	18	17,5	18,1	18,7	19,6	19,6	20,1	20,6	20,6	20,2	20,2	20,2	20,2
VELOCITY EXIT m/s	29	33,2	33,9	35,4	35,4	14,9	20,1	25	26,8	26,8	25	26,8	33	32,7	31,4	31,4	31,4	20,2	20,2	20,2	20,2
PRIMARY AIR kg/s	0,324	0,360	0,394	0,420	0,420	0,179	0,252	0,304	0,362	0,362	0,400	0,446	0,496	0,536	0,576	0,616	0,616	0,270	0,302	0,332	0,362
TOTAL AIR kg/s	2,654	3,040	3,080	3,230	3,230	1,358	1,830	2,280	2,430	2,430	3	3,460	4,000	4,400	4,800	5,200	5,600	1,840	2,170	2,530	2,900
AIR INDUCTION RATIO	8,2	8,4	7,8	7,7	7,7	7,6	7,3	7,5	6,7	6,7	7,5	6,6	6,6	6,6	6,9	7	6,5	6,1	5,7	5,3	5,3
TRACTION kg	7,205	8,705	10,285	11,610	11,610	1750	3,608	5,100	7	8,605	10,205	12,043	14,000	16,000	18,000	20,000	22,000	2,600	3,100	3,600	4,100
ATMOSPHERIC PRESSURE mm/Hg	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775
ATMOSPHERIC TEMPERATURE °C	18,4	18,6	18,4	18,8	18,8	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2	19,2
ATMOSPHERIC HUMIDITY %	72	71	70	70	70	69	68	68	68	68	68	68	68	68	68	68	68	55	54	54	53

SFERI COANDA

Tuyère 162.

Debit en fonction de la pression
Primary air flow as function of pressure



Pression chambre Tuyère
Pressure in nozzle chamber

0.5 kg/cm²

C.C.M. 3/4 57

LES PAPIERS CANSON France

SFERI-COANDA.

Tuyère 162

Débit total
(Total Air flow)

Débit total Kg/sec
Total Air flow

20

15

10

5

0.100

0.200

0.300

0.400

0.500

0.600

0.700

Pression chambre Tuyère
Pressure in nozzle chamber


0.8 Kg/cm^2

C.E.M. 3/4 57

LES PAPIERS CANSON France

LES PAPIERS CANSON France

SPERI-COANDA Tuyère 162 Induction




SFERI-COANDA.

Tuyère 162

Traction en fonction du débit primaire

Traction as function of pressure air flow



UNCLASSIFIED

**A
D 204074**

Armed Services Technical Information Agency

**ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA**

**FOR
MICRO-CARD
CONTROL ONLY**

3 OF 5

NOTICE: WHEN GOVERNMENT OR OTHER DRAWINGS, SPECIFICATIONS OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY RELATED GOVERNMENT PROCUREMENT OPERATION, THE U. S. GOVERNMENT THEREBY INCURS NO RESPONSIBILITY, NOR ANY OBLIGATION WHATSOEVER; AND THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED, FURNISHED, OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA IS NOT TO BE REGARDED BY IMPLICATION OR OTHERWISE AS IN ANY MANNER LICENSING THE HOLDER OR ANY OTHER PERSON OR CORPORATION, OR CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.


UNCLASSIFIED

SFERI-COANDA

TUYERE 162

OUVERTURE AU PAS 0,25 mm
 PRESSION BAROMETRIQUE 775 mm Hg
 TEMPERATURE AMBIANTE 15,7° C
 HUMIDITE RELATIVE 61 %

PRESSION	0,500 kg/cm ² (0,341 kg/s)
DANS LA	0,400 kg/cm ² (0,290 kg/s)
CHAMBRE	0,300 kg/cm ² (0,257 kg/s)
DE LA	0,250 kg/cm ² (0,230 kg/s)
TUYERE	0,200 kg/cm ² (0,185 kg/s)
ET DEBIT	0,150 kg/cm ² (0,173 kg/s)
PRESSION	0,100 kg/cm ² (0,139 kg/s)
	0,050 kg/cm ² (0,065 kg/s)



COURBE EN DEVELOPPE


200 1/2 87

SFERI-COANDA

TUYERE 162

OUVERTURE AU PAS 0,75 mm
 PRESSION BAROMETRIQUE 775 mm Hg
 TEMPERATURE AMBIANTE 12°C
 HUMIDITE RELATIVE 77%

PRESSION	0,500 kg/cm ² (0,405 kg/s)
DANS LA	0,400 kg/cm ² (0,352 kg/s)
CHAMBRE	0,300 kg/cm ² (0,294 kg/s)
DE LA	0,250 kg/cm ² (0,262 kg/s)
TUYERE	0,200 kg/cm ² (0,236 kg/s)
ET DEBIT	0,150 kg/cm ² (0,189 kg/s)
PRIMAIRE	0,100 kg/cm ² (0,163 kg/s)
	0,050 kg/cm ² (0,110 kg/s)



COURBE EN DEVELOPPE


cm 1/2 27

SFERI-COANDA

TUYERE 162

OUVERTURE AU BAS 15 mm
 PRESSION BAROMETRIQUE 775 mm/Hg
 TEMPERATURE AMBIANTE 18,2 °C
 HUMIDITE RELATIVE 72 %

PRESSION	0,400 kg/cm ² (0,420 kg/s)
DANS LA	0,350 kg/cm ² (0,334 kg/s)
CHAMBRE	0,300 kg/cm ² (0,300 kg/s)
DE LA	0,250 kg/cm ² (0,324 kg/s)
TUYERE	0,200 kg/cm ² (0,289 kg/s)
ET DEBIT	0,150 kg/cm ² (0,247 kg/s)
PRIMAIRE	0,100 kg/cm ² (0,200 kg/s)
	0,050 kg/cm ² (0,142 kg/s)




COURBE EN DEVELOPPE

SFERI-COANDA

TUYERE 162

OUVERTURE AU RAS 225 mm
 PRESSION BAROMETRIQUE 76 mm Hg
 TEMPERATURE AMBIANTE 21.3 C
 HUMIDITE RELATIVE 63 %

PRESSION	0.300 kg/cm ² (0.446 kg/s)
DANS LA	0.250 kg/cm ² (0.400 kg/s)
CHAMBRE	0.200 kg/cm ² (0.362 kg/s)
DE LA	0.150 kg/cm ² (0.304 kg/s)
TUYERE	0.100 kg/cm ² (0.252 kg/s)
ET DEBIT	0.050 kg/cm ² (0.179 kg/s)
PRINCE	



COURBE EN DEVELOPPE


CCM 2/4 BT

SFERI-COANDA

TUYERE 162

OUVERTURE AU PAS 3 --
 PRESSION BAROMETRIQUE 713 mm Hg
 TEMPERATURE AMBIANTE 21.7°C
 HUMIDITE RELATIVE 52%

PRESSION	—	0,200 kg/cm ² (0,436 kg/s)
DANS LA	---	0,150 kg/cm ² (0,366 kg/s)
CHAMBRE	----	0,100 kg/cm ² (0,296 kg/s)
DE LA	-----	0,050 kg/cm ² (0,208 kg/s)
TUYERE	
ET DEBIT	-----	
PRIMAIRE	-----	



COURBE EN DEVELOPPE


CCM 1, 87

SFERI-COANDA

TUYERE 162

OUVERTURE AU PAS 4.5 mm
 PRESSION BAROMETRIQUE 773 mm Hg
 TEMPERATURE AMBIANTE 22°C
 HUMIDITE RELATIVE 54%

PRESSION	0.150 kg/cm ² (0.450 kg/s)
DANS LA	0.100 kg/cm ² (0.302 kg/s)
CHAMBRE	0.050 kg/cm ² (0.270 kg/s)
DE LA	
TUYERE	
ET DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE


CCM 1/2 07

SFERI-COANDA

TUYERE 162

OUVERTURE AU BAS 6 mm
 PRESSION BAROMETRIQUE 773 mm Hg
 TEMPERATURE AMBIANTE 22°C
 HUMIDITE RELATIVE 53 %

PRESSION { ——— 0,100 kg/cm² (0,520 kg/s)
 DANS LA { ——— 0,050 kg/cm² (0,359 kg/s)
 CHAMBRE { ———
 DE LA { ———
 TUYERE { ———
 ET DEBIT { ———
 PREMIERE { ———



COURBE EN DEVELOPPE


CCM 1/6 87

SFERI-COANDA

TUYERE 162

OUVERTURE AU HAS 9 mm
 PRESSION BAROMETRIQUE 775 mm Hg
 TEMPERATURE AMBIANTE 22.5°C
 HUMIDITE RELATIVE 51%

PRESSION { 0.050 kg/cm² (0.405 kg/s)
 DANS LA
 CHAMBRE
 DE LA
 TUYERE
 ET DEBIT
 PRIMAIRE



COURBE EN DEVELOPPE

CCM 3/6 07


SFERI-COANDA TUYERE 202

Fente $\phi 267 \frac{7}{8}$ L circ. $0.39 \frac{7}{8}$ (Slot ϕ circ. $1 \frac{1}{2}$)
 Lèvre mobile Pas du filetage. $1.5 \frac{7}{8}$ (Adjustable wall Thread pitch)
 Ouvertures réelles (Voir Tableau) (Real opening see table)

Col de la Tuyère $\phi = 200 \frac{7}{8}$ (Throat of the nozzle)
 Sortie de la Tuyère $\phi = 375 \frac{7}{8}$ (Exit of nozzle)
 Divergent (Plastique) L. $2000 \frac{7}{8}$ (Divergent plastic)
 " " " " " $\phi = 390 \frac{7}{8}$ (" " " ")

Ouvertures réelles

$\frac{m}{m}$	$\frac{7}{8}$
0.75	= 0.75
1.5	= 1.5
2.25	= 2.25
3	= 2.8
4.5	= 3.6
6	= 4.6
9	= 7



SFERI - COANDA

NOZZLE TUYERE 202


OPENING BY PITCH mm	0,75	0,75	0,75	0,75	0,75	0,75	0,75	0,75	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,5	0,75	0,05	0,1	0,15	0,2	0,25	0,3	0,35	0,4	0,4
TEMPERATURE NOZZLE CHAMBER °C	17,7	17,7	17,7	17,5	17,1	17,4	16,5	17,2	16,5	16,9	17,1	16,8	16,6	17,7	16,6	15,8	16,6	16,6
TEMPERATURE EXIT °C	16,9	16,9	16,9	16,7	17	16,7	17,3	16,4	17,2	16,7	17,2	17,3	17,5	17,3	17,7	17,6	17,6	17,6
VELOCITY EXIT m/s	6,75	10	10,8	14,5	15,6	17,1	18,9	21,9	24,9	10,6	14	17	19,8	22,3	24,2	27,4	29,2	29,2
PRIMARY AIR kg/s	0,078	0,116	0,157	0,183	0,205	0,225	0,255	0,280	0,356	0,146	0,204	0,246	0,288	0,330	0,367	0,410	0,448	0,448
TOTAL AIR kg/s	0,980	1,452	1,567	2,100	2,260	2,480	2,740	3,180	3,620	1,545	2,040	2,480	2,970	3,230	3,510	3,920	4,240	4,240
AIR INDUCTION RATIO	12,5	12,5	10	11,5	11	11	10,8	11,3	18,2	10,6	10	10,1	9,9	9,8	9,6	9,6	9,5	9,5
TRACTION kg	0,600	1,300	1,900	2,500	3,105	3,805	5,010	6,215	7,825	1,200	2,600	4	5	060	6,005	7,305	8,005	10,410
ATMOSPHERIC PRESSURE mm/Hg	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775
ATMOSPHERIC TEMPERATURE °C	17,2	17,2	17,3	17,3	17,4	17,5	17,6	17,7	17,5	17,6	17,7	17,8	17,9	18	18	18,1	18	18
ATMOSPHERIC HUMIDITY %	79	79	79	78	78	78	77	76	75	75	75	75	75	75	75	74	74	74

OPENING BY PITCH mm	2,25	2,25	2,25	2,25	2,25	2,25	2,25	2,25	3	3	3	3	3	3	3	3	3	3
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,15	0,2	0,25	0,3	0,05	0,1	0,15	0,2	0,05	0,1	0,15	0,2	0,05	0,1	0,15	0,15
TEMPERATURE NOZZLE CHAMBER °C	16,9	16,8	16,3	19,4	19,4	19,4	14,8	17,1	17,1	16,4	16,9	17,3	15,1	14,9	17,3	15,1	14,9	14,9
TEMPERATURE EXIT °C	16,8	17,6	17,6	17,9	17,6	17,6	17,4	17,3	17,5	17,5	17,5	17,4	17,3	17,1	17,7	17,5	17,1	17,1
VELOCITY EXIT m/s	11,5	16,2	19,7	28,4	26,5	30,2	12,7	17,9	23,4	27,2	27,2	12,7	17,9	23,4	15,9	22,4	28,2	28,2
PRIMARY AIR kg/s	0,189	0,273	0,336	0,420	0,450	0,495	0,257	0,348	0,435	0,515	0,515	0,257	0,348	0,435	0,345	0,502	0,638	0,638
TOTAL AIR kg/s	1,680	2,350	2,860	3,240	3,840	4,400	1,850	2,600	3,400	3,840	3,840	1,850	2,600	3,400	2,505	3,250	4,080	4,080
AIR INDUCTION RATIO	8,8	8,6	8,5	7,7	8,5	8,9	7,8	7,5	7,8	7,6	7,6	7,8	7,5	7,8	6,7	6,5	6,4	6,4
TRACTION kg	1,6	3,4	5,2	7,2	9,205	11,205	2	4,4	7,2	9,6	9,6	2	4,4	7,2	3	6,8	9,8	9,8
ATMOSPHERIC PRESSURE mm/Hg	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775
ATMOSPHERIC TEMPERATURE °C	18	18	18	18	18	18,2	18,3	18,3	18,3	18,2	18,2	18,3	18,3	18,3	18,3	18,3	18,2	18,2
ATMOSPHERIC HUMIDITY %	74	74	73	73	73	72	72	72	72	72	72	72	72	72	73	74	74	74

SFERI COANDA.

Tuyère 202

Débit en fonction de la pression
Primary Air flow as function of pressure




SPERI-COANDA.

Tuyère 202

*Débit total
(Total Air flow)*

*Débit total Kg/sec.
Total Air flow*



Pression chambre Tuyère
Pressure in nozzle chamber
0.8 Kg/cm²

LES PAPIERS CANSON France

C.C.M. 3/4 57

SFERI-COANDA Tuyère 202 Induction


Induction

20

15

10

5



0.100

0.200

0.300

0.400

0.500

0.600


0.700

Pression chambre Tuyère
Pressure in nozzle chamber
0.8 Kg/cm²
C.C.M. 3/4 57

LES PAPIERS CANSON FRANCE

Tuyère 202


Traction en fonction du débit primaire
Traction as function of pressure air flow



SFERI-COANDA TUYERE 202

OUVERTURE AU PAS 0,75 mm
PRESSION BAROMETRIQUE 775 mm Hg
TEMPERATURE AMBIANTE 17,4°C
HUMIDITE RELATIVE 78%

PRESSION	0,750 kg/cm ² (0,956 kg/s)
DANS LA	0,500 kg/cm ² (0,638 kg/s)
CHAMBRE	0,400 kg/cm ² (0,510 kg/s)
DE LA	0,300 kg/cm ² (0,382 kg/s)
TUYERE	0,250 kg/cm ² (0,319 kg/s)
ET DEBIT	0,200 kg/cm ² (0,255 kg/s)
PRIMAIRE	0,150 kg/cm ² (0,191 kg/s)
	0,100 kg/cm ² (0,127 kg/s)
	0,050 kg/cm ² (0,064 kg/s)



COURBE EN DEVELOPPE


CEM 1/4 07

SFERI-COANDA

TUYERE 202

OUVERTURE AU RAS 15 --
 PRESSION BAROMETRIQUE 775 mm/Hg
 TEMPERATURE AMBIANTE 17,8° C
 HUMIDITE RELATIVE 75 %

PRESSION	0,400 kg/cm ² (0,448 kg/s)
DANS LA	0,350 kg/cm ² (0,410 kg/s)
(NOMBRE	0,300 kg/cm ² (0,367 kg/s)
DE LA	0,250 kg/cm ² (0,330 kg/s)
TUYERE	0,200 kg/cm ² (0,288 kg/s)
ET DEBIT	0,150 kg/cm ² (0,246 kg/s)
PRIMAIRE	0,100 kg/cm ² (0,204 kg/s)
	0,050 kg/cm ² (0,146 kg/s)



COURBE EN DEVELOPPE


ccm 1/2 07

SFERI-COANDA

TUYERE 202

OUVERTURE AU PAS 225 mm
 PRESSION BAROMETRIQUE 775 mm Hg
 TEMPERATURE AMBIANTE 19°C
 HUMIDITE RELATIVE 73%

PRESSION	0,300 kg/cm ² (0,485 kg/s)
DAVIS LA	0,250 kg/cm ² (0,450 kg/s)
CHAMBRE	0,200 kg/cm ² (0,400 kg/s)
DE LA	0,150 kg/cm ² (0,336 kg/s)
TUYERE	0,100 kg/cm ² (0,273 kg/s)
ET DEBIT	0,050 kg/cm ² (0,109 kg/s)
PROFONDITE	




COURBE EN DEVELOPPE

SFERI-COANDA

TUYERE 202

OUVERTURE AU PAS 3 mm
 PRESSION BAROMETRIQUE 775 mm Hg
 TEMPERATURE AMBIANTE 18.5°C
 HUMIDITE RELATIVE 72%

PRESSION	—	0,200 kg/cm ² (0,515 kg/s)
DANS LA	- - -	0,150 kg/cm ² (0,435 kg/s)
CHAMBRE	- - -	0,100 kg/cm ² (0,340 kg/s)
DE LA	0,050 kg/cm ² (0,297 kg/s)
TUYERE	—	
ET DEBIT	- - -	
PRIMAIRE	




COURBE EN DEVELOPPE

CEN 1/4 87

SFERI-COANDA TUYÈRE 202

OUVERTURE AU RAS 6.5 --
PRESSION BAROMETRIQUE 773 mm Hg
TEMPERATURE AMBIANTE 18.3 °C
HUMIDITE RELATIVE 74 %

PRESSION	—	0.30 kg/cm ² (0.630 kg/s)
DANS LA	- - -	0.100 kg/cm ² (0.502 kg/s)
CHAMBRE	- - -	0.050 kg/cm ² (0.345 kg/s)
DE LA	
TUYÈRE	—	
ET DEBIT	- - -	
PRIMAIRE	





COURBE EN DEVELOPPE

ccm 1/4 87

SFERI-COANDA
TUYERE 302 B.

Fente $\phi 400 \frac{1}{2}$ in. - 1250 % (Dial ϕ 4 in. "A")
 Lèvre mobile Bas du finage - 2 % (Adjustable with thread pitch)
 Ouvertures mobiles (Voir Tableau) (Heat opening see table)
 Col de la Tuyere ϕ - 300 % (Dial of the nozzle)
 Sortie de la Tuyere ϕ - 562 % (Dial of nozzle)
 Divergent (Divergent) L. - 1500 % (Divergent nozzle)
 ϕ - 520 %



Sortie - 400%

Openings in inches	%
0.5	0.5
1	1
1.5	1.5
2	2
3	3
4	4.3
5	5

SFERI - COANDA NOZZLE TUYERE 302 BIS

OPENING BY PITCH mm	0,5	0,5	0,5	0,5	0,5	0,5	1	1	1	1	1,5	1,5	1,5	1,5
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,05	0,1	0,15	0,2	0,25	0,3	0,35
TEMPERATURE NOZZLE CHAMBER °C	17,0	18,1	18,1	17,9	18,1	17,9	18,4	17,0	17,6	18,2	17,9	17,9	17,5	17,2
TEMPERATURE EXIT °C	17	17,1	16,9	17,1	17,1	17,5	16,9	17,1	17	17	17,7	17,9	17,9	17
VELOCITY EXIT m/s	5,7	7,2	8,6	9,3	10,6	12,6	13,8	7,2	9,7	12,3	19,3	14,2	7,6	11,4
PRIMARY AIR kg/s	=0,04	0,071	0,086	0,119	0,134	0,147	0,172	0,102	0,157	0,194	0,220	0,256	0,156	0,220
TOTAL AIR kg/s	1,76	2,23	2,67	2,89	3,27	3,9	4,28	2,21	2,98	3,8	4,1	4,38	2,35	3,52
AIR INDUCTION RATIO	=44	31,4	27,8	24,3	24,4	26,5	24,9	21,7	19	19,6	18	17,1	15,1	16
TRACTION kg	0,4	0,8	1,36	2,1	2,705	3,205	4,21	0,8	2	3,08	4,44	5,725	1,4	3,04
ATMOSPHERIC PRESSURE mm/Hg	756	756	756	756	756	756	756	756	756	756	756	755	755	755
ATMOSPHERIC TEMPERATURE °C	18,3	18,5	18,5	18,5	18,5	18,5	18,5	18,5	18,6	18,6	19	19	19	19
ATMOSPHERIC HUMIDITY %	59	59	59	59	59	59	59	59	59	59	60	59	59	50


OPENING BY PITCH mm	2	2	2	2	2	3	3	3	3	4	4	4	5	5
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,15	0,2	0,2	0,05	0,1	0,15	0,2	0,05	0,1	0,15	0,05	0,1
TEMPERATURE NOZZLE CHAMBER °C	17,5	17,2	17,1	17,1	17,1	17,3	17,1	16,5	16,4	17,3	17,1	16,8	16,7	16,5
TEMPERATURE EXIT °C	17	16,5	17,1	17	17	16,7	17	17,2	17,5	17,3	18	17,8	17,3	17,9
VELOCITY EXIT m/s	9,9	13,7	17,3	18,5	18,5	9,3	14,8	19,4	20,1	18,5	15,6	18,9	12	17,2
PRIMARY AIR kg/s	0,196	0,277	0,341	0,408	0,408	0,261	0,386	0,455	0,541	0,294	0,403	0,611	0,367	0,556
TOTAL AIR kg/s	3,05	4,21	5,3	5,7	5,7	2,9	4,6	6	6,22	3,25	4,83	5,86	3,71	5,85
AIR INDUCTION RATIO	15,6	15,2	15,6	14	14	11,1	11,9	13,2	11,5	11	10	9,6	10,1	9,6
TRACTION kg	2	3,8	5,84	8,6	8,6	2,48	5,72	8,7	11,46	3,24	7,2	10,4	3,6	8
ATMOSPHERIC PRESSURE mm/Hg	755	755	755	755	755	755	755	755	755	755	755	755	755	755
ATMOSPHERIC TEMPERATURE °C	19	19	19	19	19	19	18,9	18,8	18,9	18,8	18,8	18,8	18,8	18,8
ATMOSPHERIC HUMIDITY %	58	58	58	58	58	58	58	58	58	57	57	57	57	57

CCM 3/4 57


SFERI-COANDA.

Tuyère 302.^B

Débit en fonction de la pression
Primary Air flow as function of pressure




SFERI-COANDA.
 Tuyère 302.^B
 Debit total.
 Total air flow)



Pression chambre Tuyère
 Pressure in nozzle chamber
 0.8 kg/cm²
 C.C.M. 3/4 57

SFERI COANDA
Tuyère 302^B
Induction




Pression chambre Tuyère
 Pressure in nozzle chamber
 0.8 kg/cm²
 C.C.M. 3/4 57

SFERI-COANDA

Tuyère 302 B

Traction en fonction du débit primaire

Traction as function of pressure air flow



SFERI-COANDA

TUYERE 302 °


OUVERTURE AU PAS 0,5 mm

PRESSION BAROMETRIQUE 756 mm/Hg

TEMPERATURE AMBIANTE 18,5 °C

HUMIDITE RELATIVE 59%

PRESSION	0,400 kg/cm ² (0,172 kg/s)
AVANT LA	0,300 kg/cm ² (0,147 kg/s)
CHAMBRE	0,250 kg/cm ² (0,134 kg/s)
DE LA	0,200 kg/cm ² (0,119 kg/s)
TUYERE	0,150 kg/cm ² (0,096 kg/s)
ET DEBIT	0,100 kg/cm ² (0,071 kg/s)
PRIMAIRE	0,050 kg/cm ² (0,040 kg/s)



COURBE EN ESTRIE

cm/s

SFERI-COANDA

TUYERE 302[°]


OUVERTURE AU BAS 1[°]

PRESSIION BAROMETRIQUE 756 mm/Hg

TEMPERATURE AMBIANTE 19.6°C

HUMIDITE RELATIVE 59%

PRESSIION	0,250 kg/cm ² / 0,256 kg/s
DANS LA	0,200 kg/cm ² / 0,228 kg/s
CHAMBRE	0,150 kg/cm ² / 0,194 kg/s
DE LA	0,100 kg/cm ² / 0,157 kg/s
TUYERE	0,050 kg/cm ² / 0,102 kg/s
ET DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE

ccm 1/2 07

SFERI-COANDA

TUYERE 302 °


OUVERTURE AU RAS 1,5 °

PRESSION BAROMETRIQUE 755 mm/Hg

TEMPERATURE AMBIANTE 19 °C

HUMIDITE RELATIVE 59 %

PRESSION	0,250 kg/cm ²	(0,364 g/s)
DANS LA	0,200 kg/cm ²	(0,311 g/s)
TUYERE	0,150 kg/cm ²	(0,267 g/s)
DE LA	0,100 kg/cm ²	(0,220 g/s)
TUYERE	0,050 kg/cm ²	(0,156 g/s)
ET DEBIT		
PRIMAIRE		



COURBE EN DEVELOPPE

CCM 1/4 07

SFERI-COANDA

TUYERE 302 °


OUVERTURE AU PAS 2°

PRESSION BAROMETRIQUE 755 mm/Hg

TEMPERATURE AMBIANTE 19° C

HUMIDITE RELATIVE 58 %

PRESSION	0,200 kg/cm ² (0,408 kg/s)
DE LA	0,150 kg/cm ² (0,341 kg/s)
CHAMBRE	0,100 kg/cm ² (0,277 kg/s)
DE LA	0,050 kg/cm ² (0,196 kg/s)
TUYERE	
ET DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE

ccm 2/07

SFERI-COANDA

TUYERE 302 °


OUVERTURE AU BAS 1 mm

PRESSION BAROMETRIQUE 755 mm Hg

TEMPERATURE AMBIANTE 18,9 °C

HUMIDITE RELATIVE 58 %

PRESSION	0,200 kg/cm ² (0,541 kg/s)
ANS LA	0,150 kg/cm ² (0,455 kg/s)
(NOMBRE	0,100 kg/cm ² (0,386 kg/s)
DE LA	0,050 kg/cm ² (0,261 kg/s)
TUYERE	
ET DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE

ccm 1/2 07

SFERI-COANDA

TUYERE 302 °


OUVERTURE AU BAS 4 mm

PRESSION BAROMETRIQUE 755 mm Hg

TEMPERATURE AMBIANTE 19.9 °C

HUMIDITE RELATIVE 57.9%

PRESSION	—	0.150 kg/cm ² / 0.611 kg/s
DANS LA	---	0.100 kg/cm ² / 0.483 kg/s
(NOMBRE	----	0.050 kg/cm ² / 0.294 kg/s)
DE LA	-----	
TUYERE	-----	
ET DEBIT	-----	
PRIMAIRE	-----	



COURBE EN DEVELOPPE

CCM 1/8 07

SFERI-COANDA

TUYERE 302


OUVERTURE AU PAS 3

PRESSION BAROMETRIQUE 753

TEMPERATURE AMBIANTE 16.9 °C

HUMIDITE RELATIVE 57 %


PRESSION : ——— 0.100 kg/cm² (0.556 kg/s)
 DANS LA : ——— 0.050 kg/cm² (0.367 kg/s)
 CHAMBRE : ———
 DE LA : ———
 TUYERE : ———
 ET DEBIT : ———
 PRIMAIRE : ———



COURBE EN DEVELOPPE

CCM 1/4 07

SFERI-COANDA TUYERE 104



SFERI - COANDA NOZZLE TUYERE 104


OPENING BY PITCH mm	0,75	0,75	0,75	0,75	0,75	1,5	1,5	1,5	1,5	1,5	1,5	2,25	2,25	2,25	2,25	2,25	2,25
PRESSURE NOZZLE CHAMBER $\frac{mm}{cm^2}$	0,1	0,3	0,6	0,8	1	0,1	0,2	0,3	0,4	0,5	0,75	0,1	0,2	0,3	0,4	0,5	0,75
TEMPERATURE NOZZLE CHAMBER °C	—	—	15,1	14,5	14,7	15	15,6	14,8	15	14,9	14,6	15,3	15,3	15,5	15,4	15,5	15,3
TEMPERATURE EXIT °C	—	—	14,4	16,2	16,2	15,4	15,4	16,4	16,2	15,9	16,5	16	16,2	16,8	17	16,9	17,2
VELOCITY EXIT $\frac{m}{s}$	—	10,2	31,2	32,3	35,8	16,3	23,3	27,1	33,4	35,9	42,3	19,5	26	32,8	39,6	43,5	47,7
PRIMARY AIR $\frac{kg}{s}$	<0,02	0,058	0,091	0,100	0,126	0,063	0,100	0,121	0,142	0,157	0,196	0,101	0,145	0,176	0,205	0,231	0,290
TOTAL AIR $\frac{kg}{s}$	—	0,667	1,140	1,177	1,305	0,597	0,852	0,992	1,220	1,310	1,548	0,732	0,950	1,200	1,440	1,500	1,796
AIR INDUCTION RATIO	—	11,5	12,5	14,9	10,4	9,5	8,5	8,2	8,6	8,3	7,9	7,1	6,7	6,8	7	6,8	5,8
TRACTION $\frac{kg}{kg}$	0,680	1,605	3,085	3,935	4,635	1,020	2	2,065	3,010	4,615	6,425	1,720	2,700	3,705	5,110	6,315	8,025
ATMOSPHERIC PRESSURE $\frac{mm}{Hg}$	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769
ATMOSPHERIC TEMPERATURE °C	16,1	15,4	15,6	15,8	16	16,2	16,3	16,6	16,8	17	17,2	17,3	17,4	17,5	17,6	17,8	18
ATMOSPHERIC HUMIDITY %	84	85	85	85	84	83	83	83	83	82	81	81	80	80	80	79	79

OPENING BY PITCH mm	3	3	3	3	3	4,5	4,5	4,5	4,5	4,5	4,5	6	6	6	6	9	9
PRESSURE NOZZLE CHAMBER $\frac{mm}{cm^2}$	0,1	0,2	0,3	0,4	0,5	0,1	0,2	0,3	0,4	0,5	0,75	0,1	0,2	0,3	0,4	0,5	0,75
TEMPERATURE NOZZLE CHAMBER °C	15,5	15,7	15,3	15,2	16,5	15,8	15,6	15	14,5	14,7	15,8	15,8	15,2	15,7	14,4	16,3	15,5
TEMPERATURE EXIT °C	16,6	16,9	17,4	17,4	17,5	16,9	17,1	17,7	17,7	17,8	17,5	17,5	17,6	17,6	17,8	17,8	17,5
VELOCITY EXIT $\frac{m}{s}$	21,9	31,7	39	42,2	48	27,2	30,8	44,8	49,2	54,3	29,9	40	47	54,9	54,9	20,4	27,5
PRIMARY AIR $\frac{kg}{s}$	0,145	0,194	0,241	0,273	0,304	0,218	0,304	0,365	0,420	0,472	0,300	0,413	0,503	0,565	0,565	0,297	0,444
TOTAL AIR $\frac{kg}{s}$	0,795	1,150	1,415	1,530	1,740	0,987	1,408	1,628	1,782	1,965	1,082	1,450	1,710	1,990	1,990	0,740	1
AIR INDUCTION RATIO	5,5	5,9	5,9	5,6	5,7	4,5	4,6	4,5	4,2	4,2	3,6	3,5	3,4	3,5	3,5	2,5	2,4
TRACTION $\frac{kg}{kg}$	1,800	3,160	4,805	6,410	7,410	2,320	4,500	5,705	7,910	8,690	2,900	5,300	7,505	8,610	8,610	1,400	2,400
ATMOSPHERIC PRESSURE $\frac{mm}{Hg}$	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769	769
ATMOSPHERIC TEMPERATURE °C	18,2	18,4	18,6	18,8	19	19,2	19,4	19,6	19,8	20	20,1	20,2	20,4	20,6	20,6	20,8	21
ATMOSPHERIC HUMIDITY %	78	77	77	76	76	75	75	74	73	72	71	70	70	69	69	68	67

SFERI COANDA.

Tuyère 104

Débit en fonction de la pression
Primary air flow as function of pressure




Débit total Kg/sec
Total Air flow.

SFERI COANDA.

Tuyère 104

Débit total
(Total Air flow)




Pression chambre Tuyère
Pressure in nozzle chamber
0.5 Kg/cm²
C.C.M. 3/4 57

SFERI-COANDA.

Tuyère 104


Induction



SFERI-COANDA.

Tuyère 104


Traction en fonction du débit primaire
Traction as function of primary air flow



SFERI-COANDA TUYERE 104

OUVERTURE AU PAS 0.75 mm
PRESSION BAROMETRIQUE 769 mm/Hg
TEMPERATURE AMBIANTE 15.7 °C
HUMIDITE RELATIVE 85 %

PRESSION (_____	1 g/cm ²	(0.126 g/s)
DANS LA	_____	0.8 g/cm ²	(0.100 g/s)
CHAMBRE	_____	0.6 g/cm ²	(0.091 g/s)
DE LA	_____	0.3 g/cm ²	(0.050 g/s)
TUYERE	_____		
ET DEBIT	_____		
PRIMAIRE	_____		



COINCE EN DEVELOPPE
C.C.M. 5/ 87

SFERI-COANDA TUYERE 104


OUVERTURE AU PAS 15 mm

PRESSION BAROMETRIQUE 769 mmHg

TEMPERATURE AMBIANTE 16.8 °C

HUMIDITE RELATIVE 83 %

PRESSION	0.750 g/cm ²	(0.196 g/s)
DANS LA	0.500 g/cm ²	(0.157 g/s)
CHAMBRE	0.400 g/cm ²	(0.142 g/s)
DE LA	0.300 g/cm ²	(0.121 g/s)
TUYERE	0.200 g/cm ²	(0.100 g/s)
ET DEBIT	0.100 g/cm ²	(0.063 g/s)
PRIMAIRE		



COURBE EN DEVELOPPE
CCM 3/6 87

SFERI-COANDA TUYERE 104


OUVERTURE AU PAS 2,25 mm

PRESSION BAROMETRIQUE 769 mm/Hg

TEMPERATURE AMBIANTE 17,6 °C

HUMIDITE RELATIVE 80 %

PRESSION	0,750 kg/cm ²	(0,298 kg/s)
DANS LA	0,500 kg/cm ²	(0,231 kg/s)
CHAMBRE	0,400 kg/cm ²	(0,205 kg/s)
DE LA	0,300 kg/cm ²	(0,176 kg/s)
TUYERE	0,200 kg/cm ²	(0,145 kg/s)
ET DE LA	0,100 kg/cm ²	(0,101 kg/s)
PRIMAIRE		



COURBE EN DEVELOPPE
C.L. 2/2, 57

SFERI-COANDA

TUYERE 104


OUVERTURE AU PAS 3"

PRESSION BAROMETRIQUE 760 mm/Hg

TEMPERATURE AMBIANTE 18,6 °C

HUMIDITE RELATIVE 77 %

PRESSION (0,500 kg/cm ²	(0,304 kg/s)
DANS LA	0,400 kg/cm ²	(0,273 kg/s)
CHAMBRE	0,300 kg/cm ²	(0,241 kg/s)
DE LA	0,200 kg/cm ²	(0,194 kg/s)
TUYERE	0,100 kg/cm ²	(0,145 kg/s)
ET DEBIT		
PRIMAIRE		



CONTRÔLE EN DÉVELOPPE
C.C.M. 1/2 87

SFERI-COANDA

TUYERE 104


OUVERTURE AU PAS 4,5 mm

PRESSIION BAROMETRIQUE 760 mm/Hg

TEMPERATURE AMBIANTE 19,6 °C

HUMIDITE RELATIVE 74 %

PRESSIION	0,500 kg/cm ²	(0,472 kg/s)
DANS LA	0,400 kg/cm ²	(0,420 kg/s)
CHAMBRE	0,300 kg/cm ²	(0,365 kg/s)
DE LA	0,200 kg/cm ²	(0,306 kg/s)
TUYERE	0,100 kg/cm ²	(0,218 kg/s)
ET DEBIT		
PRIMAIRE		



CORRECTION EN DEVELOPPE
C.C.M. 1/2 87

SFERI-COANDA

TUYERE 104


OUVERTURE AU PAS 6"

PRESSION BAROMETRIQUE 769 mm/Hg

TEMPERATURE AMBIANTE 20,3° C

HUMIDITE RELATIVE 70 %

PRESSION	0,400 kg/cm ²	(0,565 kg/s)
DANS LA	0,300 kg/cm ²	(0,505 kg/s)
CHAMBRE	0,200 kg/cm ²	(0,413 kg/s)
DE LA	0,100 kg/cm ²	(0,300 kg/s)
TUYERE		
ET DEBIT		
PRIMAIRE		



COMME EN DEVELOPPE
C.C.M. 2/2 87

SFERI-COANDA TUYERE 104


OUVERTURE 21 PAS 9"

PRESSION BAROMETRIQUE 769 mm/Hg

TEMPERATURE AMBIANTE 20.9°C

HUMIDITE RELATIVE 67%

PRESSION	0.400 kg/cm ² (0.414 kg/s)
DANS LA	0.050 kg/cm ² (0.297 kg/s)
CHAMBRE	
DE LA	
TUYERE	
ET DEBIT	
PRIMAIRE	




COURBE EN DEVELOPPE
CCH 2/87

SFERI-COANDA TUYERE 164

Fente ϕ 214 $\frac{7}{16}$ circ - 672 $\frac{7}{16}$ (Slot ϕ circ " ")
 Lèvre mobile Pas du filetage - 1 $\frac{7}{16}$ (Adjustable wall Thread pitch)
 Ouvertures réelles (Voir Tableau) (Real opening see table)


Col de la Tuyère ϕ = 160 $\frac{7}{16}$ (Throat of the nozzle)
 Sortie de la Tuyère ϕ = 300 $\frac{7}{16}$ (Exit of nozzle)
 Divergent (Dilatique) L = 1600 $\frac{7}{16}$ (Divergent portion)
 " " " " ϕ = 310 $\frac{7}{16}$ " " " "



1
 ϕ Fente
 = 214 $\frac{7}{16}$

Ouvertures réelles

$\frac{7}{16}$	$\frac{7}{16}$
075	= 075
15	= 15
225	= 22
3	= 28
45	= 41
6	= 52
9	= 78



SFERI - COANDA

NOZZLE TUYERE

164

OPENING BY PITCH mm	0,75	0,75	0,75	0,75	0,75	0,75	0,75	0,75	0,75	1,5	1,5	1,5	1,5	1,5	1,5	2,25	2,25	2,25	2,25	2,25	2,25
PRESSURE NOZZLE CHAMBER kg/cm ²	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,5	0,5	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,05	0,1	0,15	0,2	0,25
TEMPERATURE NOZZLE CHAMBER °C	14,6	14,8	15,1	15,4	14,6	14,3	14,3	14,9	14,9	17,5	17,4	18,3	17,5	18,8	17,5	16,8	16,5	17,2	17,2	16,9	16,8
TEMPERATURE EXIT °C	14,5	14,6	15,1	15,2	15,2	15,1	15,2	15,7	15,7	16,2	16,4	16,7	16,8	16,8	16,7	17	16,8	16,7	16,8	16,9	17,9
VELOCITY EXIT m/s	9,8	13,9	17,1	18,9	21,9	24,7	27,8	31,7	31,7	11,2	16,8	21,6	—	26	27,9	31,8	12,8	19,1	22,1	26,1	30,7
PRIMARY AIR kg/s	0,076	0,118	0,152	0,168	0,194	0,218	0,257	0,288	0,288	0,108	0,157	0,204	0,248	0,267	0,300	0,346	0,141	0,211	0,256	0,288	0,308
TOTAL AIR kg/s	1,170	1,665	2,042	2,255	2,610	2,945	3,310	3,780	3,780	1,330	2	2,575	—	3,088	3,280	3,760	1,545	2,260	2,615	3,080	3,680
AIR INDUCTION RATIO	15,4	14	13,4	13,4	13,4	14	12,9	13	13	12,3	12,7	12,6	—	11,5	10,9	10,9	10,7	10,7	10,2	10,3	10,5
TRACTION kg	1	1900	2880	3,880	4,605	5,405	7,210	9,315	9,315	1,140	2,450	3,880	4,900	6,205	7,605	9,934	1488	3	4,506	6,380	7,788
ATMOSPHERIC PRESSURE mm/Hg	763	763	763	763	763	763	763	763	763	762	762	762	762	762	762	762	762	762	762	762	762
ATMOSPHERIC TEMPERATURE °C	15,9	15,9	15,9	15,9	16	16,1	16,2	16	16	17,3	17,5	17,7	17,9	18,1	18,1	18,1	18,2	18,2	18,3	18,3	18,4
ATMOSPHERIC HUMIDITY %	56	56	56	56	56	55	55	55	55	50	49	49	49	49	49	49	48	48	49	49	48

OPENING BY PITCH mm	2,25	3	3	3	3	3	3	3	3	4,5	4,5	4,5	4,5	4,5	4,5	4,5	6	6	6	6	6	7,5	7,5
PRESSURE NOZZLE CHAMBER kg/cm ²	0,3	0,85	0,1	0,15	0,2	0,25	0,25	0,25	0,25	0,05	0,1	0,15	0,2	0,25	0,25	0,25	0,05	0,1	0,15	0,2	0,25	0,05	0,1
TEMPERATURE NOZZLE CHAMBER °C	16,2	17,1	16,8	16,6	16	16,2	16,2	16,2	16,2	16,8	16,5	14,5	14	13,4	13,4	13,4	17	14,7	15	14,7	15	14	14
TEMPERATURE EXIT °C	16,8	16,8	16,8	16,9	16,9	16,8	16,8	16,8	16,8	16,8	16,3	16,2	16,6	16,9	16,9	16,9	17	16,8	16,8	16,7	16,5	16,4	16,4
VELOCITY EXIT m/s	32,2	14,4	21,1	25	28	31,2	31,2	31,2	31,2	16,7	23,4	28,1	32,2	36,2	36,2	36,2	18,4	25,6	30,8	36,2	18,9	27,2	27,2
PRIMARY AIR kg/s	0,367	0,184	0,262	0,314	0,367	0,419	0,419	0,419	0,419	0,266	0,366	0,455	0,522	0,600	0,600	0,600	0,376	0,492	0,610	0,742	0,440	0,653	0,653
TOTAL AIR kg/s	3,810	1,702	2,500	2,958	3,388	3,800	3,800	3,800	3,800	1,970	2,770	3,335	3,800	4,280	4,280	4,280	2,165	3,050	3,640	4,260	2,220	3,205	3,205
AIR INDUCTION RATIO	104	9,3	9,5	9,4	8	8,8	8,8	8,8	8,8	7,3	7,6	7,3	7,3	7,1	7,1	7,1	5,8	6,2	5,9	5,7	5	4,9	4,9
TRACTION kg	9,345	1,720	3,900	5,900	7,500	9,305	9,305	9,305	9,305	2,680	5,120	7,580	9,920	12,525	12,525	12,525	3,640	6,510	9,400	12,650	3,500	7,489	7,489
ATMOSPHERIC PRESSURE mm/Hg	762	762	762	762	762	762	762	762	762	762	762	762	762	762	762	762	762	762	762	762	761	761	761
ATMOSPHERIC TEMPERATURE °C	16,2	18,2	18,3	18,4	18,6	18,4	18,4	18,4	18,4	18,4	18,5	18,3	18,2	18,4	18,4	18,4	18,5	18,5	18,6	18,6	18,4	18,2	18,2
ATMOSPHERIC HUMIDITY %	49	48	48	48	48	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	48	48

UNCLASSIFIED

**A
D 204074**

Armed Services Technical Information Agency

**ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA**

**FOR
MICRO-CARD
CONTROL ONLY**

4 OF 5


NOTICE: WHEN GOVERNMENT OR OTHER DRAWINGS, SPECIFICATIONS OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY RELATED GOVERNMENT PROCUREMENT OPERATION, THE U. S. GOVERNMENT THEREBY INCURS NO RESPONSIBILITY, NOR ANY OBLIGATION WHATSOEVER; AND THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED, FURNISHED, OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA IS NOT TO BE REGARDED BY IMPLICATION OR OTHERWISE AS IN ANY MANNER LICENSING THE HOLDER OR ANY OTHER PERSON OR CORPORATION, OR CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

UNCLASSIFIED

SFERI-COANDA.

Tuyère 164


Débit en fonction de la pression
Primary air flow as function of pressure




SFERI-COANDA.

Tuyère 164

Débit total.
(Total Air flow)



SFERI-COANDA Tuyère 164 Induction




SFERI-COANDA

Tuyère 164

Traction en fonction du débit primaire

Traction as function of primary air flow



SFERI-COANDA

TUYERE 164


OUVERTURE AU PAS 0,75 mm

PRESSION BAROMETRIQUE 763 mm/Hg

TEMPERATURE AMBIANTE 16 °C

HUMIDITE RELATIVE 56 %

PRESSION	0,500 kg/cm ²	(0,285 kg/s)
DANS LA	0,400 kg/cm ²	(0,257 kg/s)
CHAMBRE	0,300 kg/cm ²	(0,210 kg/s)
DE LA	0,250 kg/cm ²	(0,194 kg/s)
TUYERE	0,200 kg/cm ²	(0,168 kg/s)
ET DEBIT	0,150 kg/cm ²	(0,152 kg/s)
PRIMAIRE	0,100 kg/cm ²	(0,1185 kg/s)
	0,050 kg/cm ²	(0,076 kg/s)



COURBE EN DEVELOPPE
C.C. 10 3/4 87

SFERI-COANDA TUYERE 164

OUVERTURE AU PAS 15°


PRESSIION BAROMETRIQUE 762 mm/Hg

TEMPERATURE AMBIANTE 17,9 °C

HUMIDITE RELATIVE 49 %

PRESSIION (0,400 g/cm ²	(0,346 g/s)
DANS LA	0,300 g/cm ²	(0,300 g/s)
CHAMBRE	0,250 g/cm ²	(0,257 g/s)
DE LA	0,200 g/cm ²	(0,200 g/s)
TUYERE	0,150 g/cm ²	(0,204 g/s)
ET DEBIT	0,100 g/cm ²	(0,157 g/s)
PRIMAIRE	0,050 g/cm ²	(0,108 g/s)

PRESSIIONS
EN
THERM D'EAU




COUPE EN DEVELOPPE
C.G.M. 4/5 87

SFERI-COANDA TUYERE 164

OUVERTURE AU PAS 525 mm
PRESSION BAROMETRIQUE 762 mmHg
TEMPERATURE AMBIANTE 18.3 °C
HUMIDITE RELATIVE 49 %

PRESSION	0.300 g/cm ² (0.867 g/s)
DANS LA	0.250 g/cm ² (0.565 g/s)
CHAMBRE	0.200 g/cm ² (0.298 g/s)
DE LA	0.150 g/cm ² (0.256 g/s)
TUYERE	0.100 g/cm ² (0.211 g/s)
ET DEBIT	0.050 g/cm ² (0.101 g/s)
PRIMAIRE	



COUPE EN DEVELOPPE
CCM 1/2 87

SFERI-COANDA TUYERE 164


OUVERTURE AU PAS 3"

PRESSIION BAROMETRIQUE 762 mm/Hg

TEMPERATURE AMBIANTE 18.4°C

HUMIDITE RELATIVE 48 %


PRESSIION	0,250 g/cm ²	(0,419 g/s)
DANS LA	0,200 g/cm ²	(0,367 g/s)
CHAMBRE	0,150 g/cm ²	(0,316 g/s)
DE LA	0,100 g/cm ²	(0,262 g/s)
TUYERE	0,050 g/cm ²	(0,184 g/s)
ET DEBIT		
PRIMAIRE		



COINCE EN DEVELOPPE
C.C.M. 2/4 BT

SFERI-COANDA TUYERE 164

OUVERTURE AU PAS 45 mm
PRESSION BAROMETRIQUE 762 mm/Hg
TEMPERATURE AMBIANTE 18.3 °C
HUMIDITE RELATIVE 47%




COURBE EN DEVELOPPE
CCM 3/4 87

SFERI-COANDA TUYERE 164

OUVERTURE AU PAS 6 mm
PRESSION BAROMETRIQUE 762 mm/Hg
TEMPERATURE AMBIANTE 18.6 °C
HUMIDITE RELATIVE 47%

PRESSION	0.200 kg/cm ² (0.742 kg/s)
DANS LA	0.150 kg/cm ² (0.618 kg/s)
CHAMBRE	0.100 kg/cm ² (0.492 kg/s)
DE LA	0.050 kg/cm ² (0.376 kg/s)
TUYERE	
ET DEBIT	
PRIMAIRE	




SFERI-COANDA TUYERE 164

OUVERTURE AU PAS 75 mm
PRESSION BAROMETRIQUE 761 mm/Hg
TEMPERATURE AMBIANTE 18,3°C
HUMIDITE RELATIVE 47%

PRESSION	_____	0,100 kg/cm ² (0,655 g/s)
DANS LA	_____	0,050 kg/cm ² (0,448 g/s)
CHAMBRE	_____	
DE LA	_____	
TUYERE	_____	
ET DEBIT	_____	
PRIMAIRE	_____	

PRESSIONS
EN
mm D'EAU





COURBE EN DEVELOPPE
C.C.M. 3/6 87

SFERI-COANDA TUYERE 204

Fente ϕ 267 7/8 circ. 0.39% (Slot ϕ circ. 1/8)
 Lavre mobile Bas de filetage 1.5% (Adjustable wall Thread pitch)
 Ouvertures rectilignes (Van Tabeau) (Real opening see table)

Col de la Tuyere ϕ = 200 7/8 (Throat of the nozzle)
 Sortie de la Tuyere ϕ = 375 7/8 (Exit of nozzle)
 Divergent (Plastique) L = 2000 7/8 (Divergent plastic)

mm	in
0.35	0.013
1.5	1/16
2.25	2/32
3	3/32
4.5	4/32
6	5/32
9	7/32



SFERI - COANDA NOZZLE TUYERE 204

OPENING BY PITCH mm	0,75	0,75	0,75	0,75	0,75	0,75	0,75	0,75	0,75	1,5	1,5	1,5	1,5	1,5	1,5	1,5	1,5
PRESSURE NOZZLE CHAMBER $\frac{mm}{kg}$	0,1	0,15	0,2	0,25	0,3	0,4	0,5	0,75	1	0,05	0,1	0,15	0,2	0,25	0,3	0,35	0,4
TEMPERATURE NOZZLE CHAMBER $^{\circ}C$	11,1	10,8	10,3	10,3	10,3	10,1	9,7	9,7	9,7	10,1	9,7	9,4	9,4	9,7	9,3	9,7	9,7
TEMPERATURE EXIT $^{\circ}C$	9,2	9,3	9,3	9,5	9,5	9,5	10,2	10,2	10,7	10,1	10,3	11,1	10,9	10,8	11,5	11,7	11,7
VELOCITY EXIT $\frac{mm}{s}$	9	10,9	13,9	12,3	12,5	15,6	17,7	19	23,8	11,5	13,6	16,2	18,2	20,8	22,7	23,9	26,3
PRIMARY AIR $\frac{kg}{s}$	0,116	0,137	0,153	0,169	0,182	0,212	0,228	0,271	0,301	0,143	0,201	0,243	0,273	0,317	0,351	0,370	0,407
TOTAL AIR $\frac{kg}{s}$	1,345	1,628	2,060	1,840	1,865	2,330	2,620	2,815	3,530	1,710	2,180	2,405	2,690	3,090	3,360	3,540	3,900
AIR INDUCTION RATIO	11,6	11,9	13,5	10,9	10,2	11	11,5	10,4	11,7	11,9	10,8	9,9	9,8	9,7	9,6	9,6	9,6
TRACTION kg	1,240	1,700	2,200	2,750	3,085	3,610	4,415	6,225	8,035	1,400	2,700	4	5,200	6,585	7,785	8,710	9,710
ATMOSPHERIC PRESSURE $\frac{mm}{kg}$	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775
ATMOSPHERIC TEMPERATURE $^{\circ}C$	11,1	11,1	11,1	10,9	11	11,4	11,6	11,8	11,8	11,7	11,7	11,7	11,8	11,9	12,1	12,2	12,3
ATMOSPHERIC HUMIDITY %	85	86	88	90	90	91	90	90	90	91	91	91	91	91	91	92	92

OPENING BY PITCH mm	2,25	2,25	2,25	2,25	2,25	2,25	2,25	3	3	3	3	3	3	3	3	3	3
PRESSURE NOZZLE CHAMBER $\frac{mm}{kg}$	0,05	0,1	0,15	0,2	0,25	0,3	0,3	0,05	0,1	0,15	0,2	0,25	0,25	0,25	0,25	0,25	0,25
TEMPERATURE NOZZLE CHAMBER $^{\circ}C$	10,1	10,1	9,6	9,5	8,7	9,5	9,5	11,1	11,1	10,4	9,5	9,5	9,5	9,5	9,5	9,5	9,5
TEMPERATURE EXIT $^{\circ}C$	11,2	11,4	11,9	12	12,5	12,6	12,6	11,9	12,2	12,8	13	13,1	13,1	13,1	13,1	13,1	13,1
VELOCITY EXIT $\frac{mm}{s}$	11,9	17,1	20,9	23	25,6	28,1	28,1	12,1	17,9	22,8	25,5	28	28	28	28	28	28
PRIMARY AIR $\frac{kg}{s}$	0,206	0,301	0,364	0,411	0,470	0,525	0,525	0,258	0,369	0,474	0,530	0,540	0,540	0,540	0,540	0,540	0,540
TOTAL AIR $\frac{kg}{s}$	1,770	2,530	3,090	3,410	3,750	4,300	4,300	1,785	2,642	3,360	3,780	4,140	4,140	4,140	4,140	4,140	4,140
AIR INDUCTION RATIO	8,6	8,4	8,5	8,3	8	8,2	8,2	6,8	7,2	7,1	7,1	7,7	7,7	7,7	7,7	7,7	7,7
TRACTION kg	2,040	4	5,800	7,900	9,705	11,805	11,805	2,500	5,100	7	9,800	12,405	12,405	12,405	12,405	12,405	12,405
ATMOSPHERIC PRESSURE $\frac{mm}{kg}$	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775	775
ATMOSPHERIC TEMPERATURE $^{\circ}C$	12,4	12,9	12,4	12,4	12,6	12,8	12,8	12,8	13	13,1	13,3	13,6	13,6	13,6	13,6	13,6	13,6
ATMOSPHERIC HUMIDITY %	92	92	92	92	93	93	93	93	92	92	92	92	92	92	92	92	92


C.C.M 3/4 57

SFERI-COANDA.

Tuyère 204

Débit en fonction de la pression
Primary Air flow as function of pressure

Débit primaire
Primary Air flow
kg/sec




Pression chambre Tuyère
Pressure in nozzle chamber
kg/cm²
C.C.M. 3/4 57

LES PAPIERS CANSON France

SFERI-COANDA

Tuyère 204

Débit total
(Total Air flow.)



Pression chambre Tuyère
Pressure in nozzle chamber
0.8 Kg/cm²
C.C.M. 3/4 57

SFERI-COANDA Tuyère 204 Induction

Induction

20

15

10

5

0.100

0.200

0.300

0.400


0.500

0.600

0.700


Pression chambre Tuyère
Pressure in nozzle chamber
0.8 Kg/cm²
C.C.M. 3/4 57

LES PAPIERS CANSON FRANCE



Tuyère 204


Traction as function of pressure air flow



SFERI-COANDA TUYERE 204

OUVERTURE AU PAS 0,75 mm
PRESSION BAROMETRIQUE 775 mm Hg
TEMPERATURE AMBIANTE 15°C
HUMIDITE RELATIVE 88%

PRESSION	1 kg/cm ²	(0,301 kg/s)
DANS LA	0,75 kg/cm ²	(0,271 kg/s)
CHAMBRE	0,5 kg/cm ²	(0,228 kg/s)
DE LA	0,4 kg/cm ²	(0,212 kg/s)
TUYERE	0,3 kg/cm ²	(0,192 kg/s)
ET DEBIT	0,25 kg/cm ²	(0,169 kg/s)
PRIMAIRE	0,20 kg/cm ²	(0,153 kg/s)
	0,15 kg/cm ²	(0,137 kg/s)
	0,10 kg/cm ²	(0,118 kg/s)



COINCE EN DEVELOPPE
C.C.M. 2/4 87


SFERI-COANDA TUYERE 204

OUVERTURE AU PAS
PRESSION BAROMETRIQUE
TEMPERATURE AMBIANTE
HUMIDITE RELATIVE

13 mm
770 mm Hg
12°C
91%

PRESSION	0,4 kg/cm ² (0,607 kg)
DANS LA	0,35 kg/cm ² (0,500 ")
CHAMBRE	0,3 kg/cm ² (0,424 ")
DE LA	0,25 kg/cm ² (0,350 ")
TUYERE	0,2 kg/cm ² (0,279 ")
ET DEBIT	0,15 kg/cm ² (0,209 ")
PRIMIERE	0,1 kg/cm ² (0,139 ")
	0,05 kg/cm ² (0,069 ")

PRESSIONS
EN
mm D'EAU




COANDA EN DEVELOPPE
C.E.M. 2/2 87

SFERI-COANDA


TUYERE 204

OUVERTURE AU PAS 2,25 mm
 PRESSION BAROMETRIQUE 775 mm Hg
 TEMPERATURE AMBIANTE 125° C
 HUMIDITE RELATIVE 92 %

PRESSION	_____	0,300 kg/cm ² (0,325 kg/s)
DANS LA	_____	0,250 kg/cm ² (0,420 kg/s)
CHAMBRE	_____	0,200 kg/cm ² (0,411 kg/s)
DE LA	_____	0,150 kg/cm ² (0,364 kg/s)
TUYERE	_____	0,100 kg/cm ² (0,381 kg/s)
ET DEBIT	_____	0,050 kg/cm ² (0,206 kg/s)
PRIMAIRE	_____	



COURBE EN DEVELOPPE
 C.E.M. 3/4 87



COINCE EN DÉVELOPPE
 C.C. 204 204

SFERI-COANDA

TUYÈRE

204

OUVERTURE AU PAS

4.5 mm

PRESSIION BAROMETRIQUE

775 mm Hg

TEMPERATURE AMBIANTE

16°C

HUMIDITE RELATIVE

92%

PRESSIION

0, 150 kg/cm²

(0, 705 kg/s)

DANS LA

0, 100 kg/cm²

(0, 530 kg/s)

CHAMBRE

0, 0.50 kg/cm²


(0, 378 kg/s)

DE LA

TUYÈRE

ET DEBIT

PA MARE



COURBE EN DEVELOPPE
CCM 2/6 87

SFERI-COANDA

TUYERE 204

OUVERTURE AU PAS
PRESSION BAROMETRIQUE
TEMPERATURE AMBIANTE
HUMIDITE RELATIVE

204

6 mm


775 mm Hg

14 °C

90 %

PRESSION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PRIMAIRE

0,020 kg/cm² (0,005 kg/s)
0,050 kg/cm² (0,013 kg/s)



COURBE EN DEVELOPPE
C.E.M. 2/6 57

SFERI-COANDA TUYERE

204

OUVERTURE AU PAS

900

PRESSIION BAROMETRIQUE

775 mm Hg

TEMPERATURE AMBIANTE


14°C

HUMIDITE RELATIVE

90%

PRESSIION
DANS LA
CHAMBRE
DE LA
TUYERE
ET DEBIT
PRIMAIRE



0,050 kg/cm² (0,556 kg/cm²)



COURBE 1^{re} DEVELOPPE
C.C. 10 1/2 87

SFERI-COANDA TUYERE 304

Fente ϕ 500% cm. 1250% (Blot ϕ 1000%)
 Leure mobile Res du fileage - 2% (Adjustable wall Throat piece)
 Ouvertures multiples (Voir Tableau) (Rad opening see Table)
 Col de la Tuyère ϕ 300% (Throat of the nozzle)
 Sortie de la Tuyère ϕ 562% (Exit of nozzle)
 Divergent (Régulé) L - 1000% (Divergent part)
 ϕ 590%



Leure mobile

1
 100%

Ouvertures multiples

%	%
0.5 - 0.5	
1 - 1	
1.5 - 1.5	
2 - 2	
3 - 3	
4 - 4	
5 - 5	



1000

SFERI - COANDA NOZZLE 304 TUYERE

OPENING BY PITCH mm	1	1	1	1	1	1	1	1	1	1,5	1,5	1,5	1,5	1,5
PRESSURE NOZZLE CHAMBER $\frac{mm}{cm^2}$	0,05	0,1	0,15	0,2	0,25	0,3				0,05	0,1	0,15	0,2	0,25
TEMPERATURE NOZZLE CHAMBER $^{\circ}C$	17,3	17	17,3	17,3	17,5	17,5				16,9	16,7	17	17,3	16,5
TEMPERATURE EXIT $^{\circ}C$	16,2	16,3	16,5	16,3	16,4	16,8				15,7	16,6	16,9	16,6	17,2
VELOCITY EXIT $\frac{mm}{s}$	7,2	9,8	11,9	12,9	15,3	17,2				6,7	11,1	15,4	16,6	16,1
PRIMARY AIR $\frac{kg}{s}$	0,115	0,168	0,198	0,234	0,262	0,288				0,168	0,287	0,289	0,336	0,382
TOTAL AIR $\frac{kg}{s}$	2,390	3,280	4,080	4,310	5,110	5,730				2,240	3,700	5,150	5,545	5,400
AIR INDUCTION RATIO	20,8	19,5	20,6	18,4	19,5	19,9				13,7	15,6	17,8	16,5	16,2
TRACTION kg	1,200	2,200	3,200	4,600	5,005	7,405				1,700	3,600	5,400	7,200	8,805
ATMOSPHERIC PRESSURE $\frac{mm}{kg}$	768	768	768	768	768	768				768	768	768	768	768
ATMOSPHERIC TEMPERATURE $^{\circ}C$	18,2	18,2	18,3	18,3	17,9	18,3				17,9	18	18	17,8	17,9
ATMOSPHERIC HUMIDITY %	44	44	44	44	44	44				43	43	44	44	44


OPENING BY PITCH mm	2	2	2	2	2	2	2	2	2	3	3	3	4	4	5
PRESSURE NOZZLE CHAMBER $\frac{mm}{cm^2}$	0,05	0,1	0,15	0,2	0,25	0,3				0,05	0,1	0,15	0,05	0,1	0,05
TEMPERATURE NOZZLE CHAMBER $^{\circ}C$	16,6	16,9	15,9	15,6	15,1	13,9				16	15,1	13,6	15	13,6	15,3
TEMPERATURE EXIT $^{\circ}C$	16,1	13,9	16,3	15,6	16,2	16,3				15,4	15,4	15,4	15	15,1	14,9
VELOCITY EXIT $\frac{mm}{s}$	7,8	12,7	14,6	18,6	18,8	18,9				10,8	15,5	15,7	12,5	17,4	13,3
PRIMARY AIR $\frac{kg}{s}$	0,221	0,311	0,374	0,437	0,498	0,544				0,296	0,427	0,505	0,368	0,555	0,718
TOTAL AIR $\frac{kg}{s}$	2,605	4,230	4,860	6,180	6,280	6,310				3,590	5,180	5,250	4,200	5,810	6,070
AIR INDUCTION RATIO	11,8	13,6	13	14,1	12,6	11,6				12,1	12,1	10,4	11,4	10,5	8,4
TRACTION kg	2	4,500	6,700	9,160	11,805	13,700				3,100	6,400	9,200	3,720	7,720	11,600
ATMOSPHERIC PRESSURE $\frac{mm}{kg}$	769	768	768	768	768	768				767	767	767	767	767	767
ATMOSPHERIC TEMPERATURE $^{\circ}C$	17,7	17,5	17,6	17,8	17,7	17,5				17,4	17,2	17,2	17	17	16,9
ATMOSPHERIC HUMIDITY %	43	43	43	43	43	43				43	43	43	49	49	43

CCM 3/4 57


SFERI-COANDA

Tuyère 304


Débit en fonction de la pression
Primary Air flow as function of pressure



Induction



SFERI-COANDA
Tuyère 304
Induction




Pression chambre Tuyère
 Pressure in nozzle chamber
 0.3 kg/cm²
 C.C.H. 3/4 57

SFERI COANDA.

Tuyère 304

Traction en fonction du débit primaire
Traction as function of pressure air flow




SFERI-COANDA TUYERE 102

Fente ϕ 167 $\frac{1}{2}$ Circ. 525 $\frac{1}{2}$ (Slot ϕ Circ^{me})
 Levre mobile Pas du filetage 1 $\frac{1}{2}$ (Adjustable wall Thread pitch)
 Ouvertures réelles (Voir Tableau) (Real opening see table)

Col de la Tuyere ϕ = 100 $\frac{1}{2}$ (Throat of the nozzle)
 Sortie de la Tuyere ϕ = 180 $\frac{1}{2}$ (Exit of nozzle)
 Divergent (Plastique) L = 1000 $\frac{1}{2}$ (Divergent plastic)

Ouvertures réelles

"	"
1	1
2	2
3	2.85
5	4
7	5.45
9	7



1000

SFERI - COANDA NOZZLE TUYERE 102

OPENING BY PITCH mm	1	1	1	1	1	1	1	1	2	2	2	2	2	2
PRESSURE NOZZLE CHAMBER kg/cm^2	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,5	0,05	0,1	0,15	0,2	0,25	0,3
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	10,4	10,4	9,8	8,9	10,5	10,4	10,1	9,9	10,4	10,2	10,4	10,2	9,9	10,4
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	9,5	10	10	9,7	9,5	9,7	10	10,1	10	10,3	10,1	10,3	10,1	10,3
VELOCITY EXIT m/s	7,1	11,3	15	17,1	19,4	21,6	25	27,6	11,8	16,8	21	24,6	26,8	28,6
PRIMARY AIR kg/s	$\pm 0,081$	$\pm 0,042$	0,058	0,072	0,090	0,100	0,127	0,143	0,053	0,098	0,116	0,137	0,158	0,170
TOTAL AIR kg/s	0,264	0,420	0,557	0,638	0,720	0,805	0,832	1,025	0,438	0,687	0,782	0,915	1	1,100
AIR INDUCTION RATIO	$\pm 12,6$	± 10	9,5	8,9	8	8	7,3	7,2	8,3	7	6,8	6,7	6,3	6,5
TRACTION kg	0,250	0,300	0,300	1,100	1,445	1,805	2,410	3,115	0,400	0,800	1,400	1,920	2,405	3,005
ATMOSPHERIC PRESSURE mm/Hg	759	759	759	759	759	759	759	759	759	759	759	759	759	759
ATMOSPHERIC TEMPERATURE $^{\circ}\text{C}$	10,4	10,4	10,4	10,4	10,4	10,4	10,4	10,4	10,4	10,6	10,6	10,6	10,7	10,7
ATMOSPHERIC HUMIDITY %	84	84	84	84	84	84	84	84	84	84	84	84	83	83


OPENING BY PITCH mm	3	3	3	3	3	3	3	3	5	5	5	5	5	5
PRESSURE NOZZLE CHAMBER kg/cm^2	0,05	0,1	0,15	0,2	0,25	0,3	0,3	0,3	0,05	0,1	0,15	0,2	0,25	0,3
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	9,5	9,5	9,8	10	9,7	9,2	9,2	9,2	10	9,2	9	9,2	8,5	8,5
TEMPERATURE NOZZLE CHAMBER $^{\circ}\text{C}$	9,7	10,4	10,4	10	10,3	10,7	10,7	10,7	10,3	10,7	10,4	10,6	10,7	10,7
VELOCITY EXIT m/s	13,3	19,9	24,1	28,4	31,1	33,3	33,3	33,3	16	24,6	29,6	33,5	36,7	37,1
PRIMARY AIR kg/s	0,076	0,132	0,159	0,191	0,206	0,228	0,228	0,228	0,143	0,212	0,260	0,291	0,338	0,420
TOTAL AIR kg/s	0,494	0,740	0,898	1,056	1,155	1,240	1,240	1,240	0,535	0,845	1,100	1,245	1,383	1,585
AIR INDUCTION RATIO	6,5	5,6	5,6	5,5	5,6	5,4	5,4	5,4	4,2	4,3	4,2	4,3	4,1	3,9
TRACTION kg	0,500	1,260	1,960	2,700	3,365	4,005	4,005	4,005	0,900	2	2,000	2	4,645	4,640
ATMOSPHERIC PRESSURE mm/Hg	758	758	758	758	758	758	758	758	758	758	758	758	758	758
ATMOSPHERIC TEMPERATURE $^{\circ}\text{C}$	10,8	10,8	10,8	10,8	10,8	11	11	11	11,2	11,2	11,3	11,4	11,4	11,6
ATMOSPHERIC HUMIDITY %	83	83	83	83	83	82	82	82	82	82	82	81	81	81

C.C.M 3/4 57

SFERI COANDA.

Tuyère 102

Débit en fonction de la pression
Primary Air flow as function of pressure



Pression chambre Tuyère
Pressure in nozzle chamber
C.E.M. 3/4 57

SFERI-COANDA.

Tuyère 102

Débit total
(Total Air flow)

Débit total, Kg/sec
Total Air flow.

20

15

10

5

9

7

6

5

4

3

2

1

op. 1

0.100

0.200

0.300

0.400

0.500

0.600


0.700

Pression chambre Tuyère
Pressure in nozzle chamber
0.8 Kg/cm²

C.C.M. 3/4 57

LES PAPIERS CANSON France

SFERI-COANDA
 Tuyère 102
 Induction




Pression chambre Tuyère
 Pressure in nozzle chamber
 0.1 kg/cm²
 C.C.M. 3/4 57

SFERI-COANDA.

Tuyère 102

Traction en fonction du débit primaire
Traction as function of pressure air flow



SFERI-COANDA

TUYERE 102


OUVERTURE AU PAS 1"

PRESSION BAROMETRIQUE 753 mm Hg

TEMPERATURE AMBIANTE 10,6 °C

HUMIDITE RELATIVE 63 %

PRESSION	0,500 g/cm ²	0,184 g/s
DANS LA	0,400 g/cm ²	0,187 g/s
CHAMBRE	0,300 g/cm ²	0,120 g/s
DE LA	0,250 g/cm ²	0,090 g/s
TUYERE	0,200 g/cm ²	0,072 g/s
ET DEBIT	0,150 g/cm ²	0,056 g/s
CHAMBRE	0,100 g/cm ²	0,048 g/s
	0,050 g/cm ²	0,021 g/s



COURBE EN DEVELOPPE

CCM 2/4 87

SFERI-COANDA

TUYERE 102


OUVERTURE AU RAS

PRESSION BAROMETRIQUE 754 mmHg

TEMPERATURE AMBIANTE 10.6 °C

HUMIDITE RELATIVE 64%

PRESSION	0.800 kg/cm ²	0.170 kg/s
DE LA	0.500 kg/cm ²	0.170 kg/s
COMBUST	0.250 kg/cm ²	0.150 kg/s
DE LA	0.200 kg/cm ²	0.137 kg/s
TUYERE	0.150 kg/cm ²	0.116 kg/s
1 ^{er} DEBIT	0.100 kg/cm ²	0.090 kg/s
2 ^{eme} DEBIT	0.050 kg/cm ²	0.058 kg/s



COUPES EN DEVELOPPE

cm 1/2 09

SFERI-COANDA

TUYERE 102


OUVERTURE AU PAS 3°

PRESSION BAROMETRIQUE 758 mm Hg

TEMPERATURE AMBIANTE 40.0 °C

HUMIDITE RELATIVE 83 %

PRESSION	0.400 kg/cm ² / 0.228 kg/s
BOUE LA	0.250 kg/cm ² / 0.206 kg/s
CORPORE	0.200 kg/cm ² / 0.191 kg/s
DE LA	0.150 kg/cm ² / 0.153 kg/s
TUYERE	0.100 kg/cm ² / 0.135 kg/s
ET DE LA	0.050 kg/cm ² / 0.076 kg/s
PRINCE DE	



COURBE EN DEVELOPPE

CONC. 0.7

TUYERE 402


OUVERTURE AU PAS 3

PRESSION BAROMETRIQUE

TEMPERATURE AMBIANTE 11.3°

HUMIDITE RELATIVE 22

PRESSION	2.0	2.0
DANS LA	1.0	1.0
CHAMBRE	1.5	1.5
DE LA	1.0	1.0
TUYERE	1.5	1.5




COURSE IN DEVELOPMENT

CCM 2/2

SFERI-COANDA TUYERE 102

OUVERTURE AU RAS
PRESSION BAROMETRIQUE 760 mm Hg
TEMPERATURE AMBIANTE 15°C
HUMIDITE RELATIVE 81%

PRESSION	0.250 g/cm ²	(0.424 g/s)
DE LA	0.150 g/cm ²	(0.366 g/s)
CHAMBRE	0.100 g/cm ²	(0.301 g/s)
DE LA	0.050 g/cm ²	(0.201 g/s)
TUYERE		
ET DEBIT		
RE-HE-RE		



COURBE EN DEVELOPPE

con 1/2 of

SFERI-COANDA

TUYERE 102


OUVERTURE AU PAB 9°

PRESSION BAROMETRIQUE 758 mm/Hg

TEMPERATURE AMBIANTE 11,8 °C

HUMIDITE RELATIVE 81%

PRESSION	0,100 g/cm ² (0,370 g/s)
DANS LA	0,050 g/cm ² (0,270 g/s)
CORRECTION	
DE LA	
TUYERE	
ET DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE


CCM 1/4 07

SFERI-COANDA TUYERE 302

Fente ϕ 362 mm Circ. - 1153 mm (Slot ϕ Circ.)
 Levre mobile Pas du filetage. 27. (Adjustable with Threadpitch)
 Ouvertures réglées (Voir Tableau) (Reg. openings see table)

Col de la Tuyere ϕ - 300 mm (Throat of the nozzle)
 Sortie de la Tuyere ϕ - 562 mm (Exit of nozzle)
 Divergent (Plastique L. - 1500 mm) (Divergent plastic)

mm	mm
0.5 - 0.5	
1 - 1	
1.5 - 1.5	
2 - 2	
3 - 2.9	
4 - 3.5	
5 - 4.1	



1200


SFERI - COANDA NOZZLE 302 TUYERE

OPENING BY PITCH mm	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	1	1	1	1	1	1,5	1,5	1,5	1,5	1,5
PRESSURE NOZZLE CHAMBER $\frac{kg}{cm^2}$	0,05	0,1	0,15	0,2	0,25	0,3	0,4	0,5	0,5	0,05	0,1	0,15	0,2	0,25	0,3	0,05	0,1	0,15	0,2
TEMPERATURE NOZZLE CHAMBER °C	11,1	11,2	11,5	11,8	11,8	11,8	11,8	11,8	11,8	10,5	10,3	10,3	10,3	9,9	9,2	9,9	9,8	9,6	11
TEMPERATURE EXIT °C	10	10	10,1	10,3	10,3	10,3	10,7	10,1	10,6	10,4	10,3	10,3	10,7	9,8	10,6	10,3	10,6	9,2	10,6
VELOCITY EXIT $\frac{m}{s}$	4	5,9	7,9	7,9	7,9	9,2	11,2	12,7	13,8	5,3	8,3	11,2	13,1	15,4	15,8	6,6	10,8	13,2	15,3
PRIMARY AIR $\frac{kg}{s}$	~0,040	0,064	0,085	0,106	0,121	0,137	0,158	0,179	0,179	0,094	0,143	0,177	0,205	0,231	0,265	0,136	0,198	0,243	0,285
TOTAL AIR $\frac{kg}{s}$	1,850	1,870	2,320	2,520	2,930	3,560	4,020	4,400	4,400	1,680	2,640	3,570	4,160	4,910	5	2,110	3,420	4,180	4,850
AIR INJECTION RATIO	~31	29,2	27,3	23,8	24,2	26	26,4	24,5	24,5	18	18,5	20,1	20,3	21,2	18,9	15,5	17,3	17,2	17
TRACTION kg	0,520	0,940	1,440	2,100	2,605	3,185	4,290	5,415	5,415	0,900	2,080	3,380	4,600	5,885	7,005	1,360	3,120	4,620	5,440
ATMOSPHERIC PRESSURE $\frac{mm}{Hg}$	759	759	759	759	759	759	759	759	759	759	759	759	759	759	759	759	759	760	760
ATMOSPHERIC TEMPERATURE °C	10,4	10,5	10,6	10,6	10,7	10,9	11	11	11	11	11	11	11	11	11	11	10,5	10,9	11
ATMOSPHERIC HUMIDITY %	81	81	81	81	81	81	81	81	82	82	82	82	82	82	82	82	82	82	82

OPENING BY PITCH mm	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	4	4	4	4	4	4	5	5	5	6
PRESSURE NOZZLE CHAMBER $\frac{kg}{cm^2}$	0,05	0,1	0,15	0,2	0,25	0,25	0,25	0,25	0,25	0,05	0,1	0,15	0,2	0,25	0,25	0,25	0,25	0,25	0,25	0,05	0,1	0,15	0,2	0,25	0,25	0,25	0,25	0,25	0,25
TEMPERATURE NOZZLE CHAMBER °C	9,5	9,5	9,1	9,1	9,1	9,1	9,1	9,1	9,1	8,9	10	10,3	9,7	9,8	9,8	9,8	9,8	9,8	9,8	10,9	10,1	10	10	10	10	10	10	10	10
TEMPERATURE EXIT °C	10,5	10,9	10,8	11,2	11,4	11,4	11,4	11,4	11,4	11,7	11,7	11,1	12,4	11,1	11,1	11,1	11,1	11,1	11,1	11,4	12,6	12	12	12	12	12	12	12	12
VELOCITY EXIT $\frac{m}{s}$	8,5	11,2	14,9	17,9	19,6	19,6	19,6	19,6	19,6	9,2	14,3	17	20,9	21	21	21	21	21	21	10,8	14,9	16,9	16,9	16,9	16,9	16,9	16,9	16,9	16,9
PRIMARY AIR $\frac{kg}{s}$	0,174	0,248	0,306	0,365	0,412	0,412	0,412	0,412	0,412	0,238	0,396	0,394	0,425	0,547	0,547	0,547	0,547	0,547	0,547	0,273	0,408	0,498	0,498	0,498	0,498	0,498	0,498	0,498	0,498
TOTAL AIR $\frac{kg}{s}$	2,700	3,560	4,540	5,680	6,200	6,200	6,200	6,200	6,200	2,920	4,530	5,360	6,600	6,600	6,600	6,600	6,600	6,600	6,600	3,420	4,710	5,310	5,310	5,310	5,310	5,310	5,310	5,310	5,310
AIR INJECTION RATIO	15,5	14,3	14,8	15,6	15	15	15	15	15	12,3	13,5	13,7	13,6	12,2	12,2	12,2	12,2	12,2	12,2	12,5	11,9	10,7	10,7	10,7	10,7	10,7	10,7	10,7	10,7
TRACTION kg	1,840	4	6,200	8,300	10,605	10,605	10,605	10,605	10,605	2,520	5,460	9,250	11,400	14,205	14,205	14,205	14,205	14,205	14,205	3,280	6,800	10,200	10,200	10,200	10,200	10,200	10,200	10,200	10,200
ATMOSPHERIC PRESSURE $\frac{mm}{Hg}$	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760	760
ATMOSPHERIC TEMPERATURE °C	11,2	11,2	11,2	11,3	11,4	11,4	11,4	11,4	11,4	11,5	11,7	12,3	12,4	12,3	12,3	12,3	12,3	12,3	12,3	12,3	12,4	12,6	12,6	12,6	12,6	12,6	12,6	12,6	12,6
ATMOSPHERIC HUMIDITY %	82	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	80	80	80	80	80	80	80	80	80

SFERI-COANDA Tuyère 302

*Débit en fonction de la pression
Primary Air flow as function of pressure*




SFERI-COANDA

Tuyère 302

Débit total
(Total air flow)

Débit total Kg/sec
(Total air flow)



Pression chambre Tuyère
Pressure in nozzle chamber
kg/cm²
C.C.M. 3/4 57

UNCLASSIFIED

**A
D 204074**

Armed Services Technical Information Agency

**ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA**


**FOR
MICRO-CARD
CONTROL ONLY**

5 OF 5

NOTICE: WHEN GOVERNMENT OR OTHER DRAWINGS, SPECIFICATIONS OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY RELATED GOVERNMENT PROCUREMENT OPERATION, THE U. S. GOVERNMENT THEREBY INCURS NO RESPONSIBILITY, NOR ANY OBLIGATION WHATSOEVER; AND THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED, FURNISHED, OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA IS NOT TO BE REGARDED BY IMPLICATION OR OTHERWISE AS IN ANY MANNER LICENSING THE HOLDER OR ANY OTHER PERSON OR CORPORATION, OR CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

UNCLASSIFIED

SFERI-COANDA.
Tuyère 302
Induction




Pression chambre Tuyère
Pressure in nozzle chamber
in kg/cm²
C.C.M. 3/4 57

SFERI-COANDA

Tuyère 302

Traction en fonction du débit primaire
Traction as function of pressure air flow




SFERI-COANDA

TUYERE 302

OUVERTURE AU RAS 0.500
 PRESSION BAROMETRIQUE 759 mm Hg
 TEMPERATURE AMBIANTE 10.7 °C
 HUMIDITE RELATIVE 81 %

PRESSION	0.500 kg/cm ² (0.173 kg/s)
DE LA	0.400 kg/cm ² (0.150 kg/s)
DE LA	0.300 kg/cm ² (0.137 kg/s)
DE LA	0.200 kg/cm ² (0.108 kg/s)
TUYERE	0.100 kg/cm ² (0.085 kg/s)
ET DEBIT	0.050 kg/cm ² (0.040 kg/s)
PRESSION	0.050 kg/cm ² (0.040 kg/s)



COURBE EN DEVELOPPE

cent 1/2

SFERI-COANDA

TUYERE


OUVERTURE AU RAS

PRESSION BAROMETRIQUE

TEMPERATURE AMBIANTE

HUMIDITE RELATIVE

PRESSION	0.300 kg/cm ² (0.265 kg/s)
DANS LA	0.250 kg/cm ² (0.231 kg/s)
CHAMBRE	0.200 kg/cm ² (0.205 kg/s)
DE LA	0.150 kg/cm ² (0.171 kg/s)
TUYERE	0.100 kg/cm ² (0.148 kg/s)
ET 0.050	0.050 kg/cm ² (0.074 kg/s)
CHAMBRE	



COURBE EN RELEVÉE


CONV. 27

SFERI-COANDA

TUYERE 302

OUVERTURE AU BAS 1,5 mm
PRESSION BAROMETRIQUE 760 mm Hg
TEMPERATURE AMBIANTE 11 °C
HUMIDITE RELATIVE 62 %

PRESSION	0,300 kg/cm ² (0,28 kg/s)
DANS LA	0,250 kg/cm ² (0,21 kg/s)
CHAMBRE	0,200 kg/cm ² (0,16 kg/s)
DE LA	0,150 kg/cm ² (0,12 kg/s)
TUYERE	0,100 kg/cm ² (0,08 kg/s)
ET DE LA	0,050 kg/cm ² (0,04 kg/s)
ARRIERE	



COURBE EN DEVELOPPE

CCM 1/8 87

SFERI-COANDA

TUYERE 302


OUVERTURE AU BAS 2 mm

PRESSION BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 16.3°C

HUMIDITE RELATIVE 81%

PRESSION	0.250 kg/cm ² (0.42 kg/s)
DANS LA	0.200 kg/cm ² (0.36 kg/s)
CHAMBRE	0.150 kg/cm ² (0.305 kg/s)
DE LA	0.100 kg/cm ² (0.248 kg/s)
TUYERE	0.050 kg/cm ² (0.174 kg/s)
ET DEBIT	
PRIMAIRE	



COURBE EN DEVELOPPE

cm 1/2 21

SFERI-COANDA

TUYERE 302


OUVERTURE AU RAS 3--

PRESSION BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 18 °C

HUMIDITE RELATIVE 81 %

PRESSION	0,250 kg/cm ² (0,567 kg/s)
DANS LA	1,200 kg/cm ² (0,445 kg/s)
CHAMBRE	0,150 kg/cm ² (0,331 kg/s)
DE LA	0,100 kg/cm ² (0,336 kg/s)
TUYERE	0,080 kg/cm ² (0,238 kg/s)
ET DEBIT	
PRESURE	



COURBE EN DEVELOPPE

1 CM = 10 mm

SFERI-COANDA

TUYERE 302


OUVERTURE AU RAS 4 mm

PRESSION BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 12.5 °C

HUMIDITE RELATIVE 80 %

PRESSION	0.150 kg/cm ² (0.435 kg/s)
DANS LA	0.100 kg/cm ² (0.400 kg/s)
CHAMBRE	0.050 kg/cm ² (0.273 kg/s)
DE LA	
TUYERE	
ET DEBIT	
PREMIERE	



COURBE EN DEVIATION


12-5-57

SFERI-COANDA

TUYERE 302

OUVERTURE AU RAS 5 mm
 PRESSION BAROMETRIQUE 100 mm Hg
 TEMPERATURE AMBIANTE 12.6 °C
 HUMIDITE RELATIVE 80 %

PRESSION 0.100 kg/cm² (0.500 kg/s)
 DANS LA 0.050 kg/cm² (0.397 kg/s)
 COURBE DE LA
 TUYERE
 ET DE LA
 PRINCIPALE



COURBE EN RELEVÉE

CON 1/2

SFERI-COANDA

TUYERE 302


OUVERTURE AU PAS 6 mm

PRESSION BAROMETRIQUE 760 mm Hg

TEMPERATURE AMBIANTE 12.7°C

HUMIDITE RELATIVE 80%

PRESSION 0.050 kg/cm² (0.420 kg/cm²)
 DANS LA CHAMBRE DE LA TUYERE ET DEBUT CHAMBRE



COANDA EN METALLURIE

CC-1/4 89

- COMMENTAIRES -

I. REMARQUES GENERALES.

Courbes de débit primaire:

Le débit primaire augmente régulièrement avec la pression et l'ouverture, ce qui est normal.

Dans la plupart des cas, l'extrapolation de ces courbes au voisinage de l'origine, c'est à dire pour une pression nulle, ne donne pas un débit primaire nul, mais il faut remarquer, et on le voit nettement sur les courbes à profil arrondi (Tuyères "I64" ou "264" par exemple), que les courbes de débit ont une pente qui varie très vite aux basses pressions (pressions inférieures à 1 Kgm. par cm²). Ces courbes ne sont donc pas extrapolables à l'origine.

Notons qu'il peut se produire des anomalies, comme c'est le cas pour la tuyère "IO4" où la courbe de débit correspondant à l'ouverture au pas de 9 mm. est située en-dessous de la courbe de débit correspondant à l'ouverture au pas de 6 mm. Cela est dû au fait qu'en dévissant le chapeau il apparaît dans la chambre de la tuyère un goulot d'étranglement dont la section peut être inférieure à la section de la fente de sortie.

Courbes de débit total :

Ici encore, le débit augmente régulièrement avec l'ouverture et la pression, du moins entre certaines limites.

La tuyère "IO2 Bis" est à ce point de vue très caractéristique. Les courbes se placent régulièrement, sauf celles correspondant aux ouvertures au pas de 3 mm. et 9 mm. La courbe d'ouverture au pas de 3 mm. présente une asymptote horizontale très nette atteinte pour une pression de 0,6 Kg./cm². La tuyère est alors saturée, c'est à dire qu'en dépit d'une augmentation continue du débit primaire, le débit total ne varie plus, donc la quantité d'air aspiré diminue. On conçoit que la tuyère perde alors de son intérêt. La courbe d'ouverture au pas de 9 mm. est plus difficile à interpréter. On voit qu'elle se situe en-dessous de la courbe d'ouverture au pas de 7 mm. La précision des mesures faites ne permet pas de conclure : en effet, quand l'ouverture augmente les courbes de débit total forment un réseau de plus en plus serré, ce qui est normal puisque le col de la tuyère reste fixe alors que l'ouverture et la pression peuvent augmenter. La mise en place des courbes de débit total aux grandes ouvertures devient donc de plus en plus délicate.

Remarquons que, contrairement aux courbes de débit total, les courbes de débit primaire ne présenteront pas d'asymptotes horizontales. En effet, alors que pour le débit total le col de la tuyère représente un goulot d'étranglement, pour le débit primaire cet obstacle ne compte pas puisque la tuyère a toujours la possibilité de refouler de l'air par l'avant (ce qui ne s'est d'ailleurs jamais produit en cours d'essais).

- COMMENTS -

I. GENERAL REMARKS.

Primary flow curves :

The primary flow increases regularly with the pressure and the opening, which is normal.

In most cases, the extrapolation of these curves in the neighborhood of the origin, i.e. for zero pressure, does not give a primary flow of zero, but it should be noted that - as may be clearly seen on the curves for the rounded profiles (e.g. nozzles "164" or "264") - that the gradient of the flow curves varies very rapidly at low pressure (below 1 Kg./cm²). These curves can therefore not be extrapolated at the origin.

It may be noted that anomalies may occur, as in the case of nozzle "104" whose flow curve corresponding to an opening by pitch of 9 mm. lies below the corresponding flow curve for an opening of 6 mm. This is due to the fact that when the cap of the nozzle is unscrewed, a constriction occurs in the chamber, which may be smaller in section than the exit slot.

Total flow curves :

Here again, the outflow increases regularly with opening and pressure, at least within certain limits.

Nozzle "102b" is very characteristic as regards this point of view. The curves are at regular intervals, except for those corresponding to openings by pitch of 3 mm. and 9 mm. The curve for an opening by pitch of 3 mm. presents a very clear horizontal asymptote when the pressure has reached 0.6 Kg./cm². The nozzle has then reached saturation point, that is to say that in spite of a continuous increase of primary flow, the total flow shows no further change; hence the amount of air induced decreases. The nozzle would therefore no longer appear to be of interest. The curve for an opening by pitch of 9 mm. is more difficult to interpret. We see that it lies below the curve for a 7 mm. opening. The accuracy of the measurements made is not sufficient to allow of definite conclusions: in fact, as the opening increases the total flow curves fall closer and closer together, which is normal since the throat of the nozzle remains fixed while the opening and the pressure can be increased. The plotting of total flow curves at very wide openings therefore become a more and more delicate operation.

It should be noted that, in contrast with the total flow curves, the primary flow curves do not present horizontal asymptotes. Actually, whereas for the total flow the throat of the nozzle represents a constriction, for the primary flow this obstacle does not count since it would always be possible for the nozzle to re-eject the air forwards (which, incidentally, has never occurred during tests).

Courbes d'induction :

Les courbes d'induction sont les moins régulières. En effet, dans le calcul de l'induction se répercutent les erreurs de mesure du débit primaire et surtout du débit total.

On constate néanmoins que les courbes se situent bien les unes au-dessus des autres quand l'ouverture diminue, ce qui montre bien l'influence du gradient de pression dans le jet sur le phénomène d'aspiration d'air : le gradient de pression dépend en effet directement de l'épaisseur du jet, c'est à dire en définitive de l'ouverture de la fente.

Pour les tuyères à profil arrondi, on constate que l'induction varie en général relativement peu avec la pression, sauf peut-être pour la tuyère "IO2 Bis" et celles du type "300" pour une ou deux ouvertures.

Pour les tuyères à facettes "I2", "I60" et "22", les courbes d'induction ont une allure générale plus marquée. On note une décroissance générale de l'induction avec la pression, ce qui semble au premier abord en contradiction avec la théorie de la turbulence, qui veut que le mouvement secondaire du fluide aspiré soit d'autant plus intense que le gradient de pression dans le jet, donc la pression dans la chambre de la tuyère, est plus élevé. C'est bien ce que confirment les courbes de débit total, la décroissance de l'induction prouvant simplement que le débit primaire augmente plus vite que le débit total quand la pression augmente, ce qui peut être dû à la fois au régime de la turbulence et à la saturation de la tuyère.

Une étude expérimentale plus précise permettrait sans doute de déterminer pour chaque tuyère et pour chaque ouverture un maximum de la courbe d'induction.

Courbes de traction :

Les courbes en traits pleins sont des courbes de traction pour une ouverture au pas constante. Ces courbes peuvent être considérées comme des résultats qualitatifs sûrs. Les courbes en traits pointillés sont des courbes de traction pour une pression constante dans la chambre de la tuyère.

Toutes ces courbes se placent régulièrement, la traction augmentant en fonction du débit, de la pression et de l'ouverture (le débit dépendant naturellement de la pression et de l'ouverture).

On constate sur les tuyères à facettes "I2", "I60" et "22", que le réseau des courbes de traction à isopress se recroisent sensiblement quand la pression devient supérieure à 2 kg./cm², ce qui semble indiquer un changement de régime quand la vitesse à la sortie de la fente devient supersonique, le gain de traction devenant de plus en plus faible en fonction de la pression.

Des essais comparatifs de traction ont été faits pour voir le rôle du divergent en matière plastique mis à la suite du divergent normal de la tuyère. Sauf une exception (tuyère "I62") sur laquelle nous reviendrons,

Induction curves :

The induction curves are the least regular. Error made in the measurements of primary and especially total flow affect the calculations of induction.

Nevertheless we note that the curves fall clearly one above the other as the opening is decreased, which plainly shows the influence of the pressure gradient in the jet on the phenomenon of air induction : the pressure gradient actually depends directly on the thickness of the jet, and thus finally on the slot opening.

For the nozzles with rounded profiles we note that in general the induction varies relatively little with pressure, except perhaps for nozzle "I02b" and the "300" type nozzle for one or two openings.

For the nozzles with facets ("I2", "I60" and "22"), the general aspect of the induction curves is better defined. We note a general decrease of induction with pressure, which at first sight would appear to be in contradiction with the theory of turbulence, which requires that the secondary flow of induced air shall increase with the pressure gradient in the jet, and thus with the pressure in the nozzle chamber. This is in fact confirmed by the total flow curves; the decrease of induction merely proves that the primary flow increases more rapidly than the total flow when the pressure is increased, which may be due both to turbulence and to the saturation of the nozzle.

In a more detailed experimental study it would doubtless be possible to establish where the induction curve for each nozzle and each opening reaches its maximum.

Traction curves :

The full lines are the traction curves for equal opening by pitch. These curves may be considered as definite qualitative results. The broken lines are the traction curves for equal pressure in the nozzle chamber.

All these curves fall at regular intervals, the traction increasing as a function of flow, pressure and opening (the flow naturally depending of the pressure and opening).

We note that for the nozzles with facets, "I2", "I60" and "22", the traction curves at equal pressures fall appreciably closer together when the pressure becomes greater than 2 Kg./cm²., which would appear to indicate a change of regime when the velocity at the exit of the slot becomes supersonic, the gain in traction becoming less and less as a function of pressure.

Comparative tests of the traction were made in order to discover the effect of the plastic divergent which had been placed after the ordinary divergent of the nozzle. With one exception (nozzle "I62"), to which we shall refer later, the tests showed that the removal of the

les essais ont montré que la suppression du divergent en matière plastique augmentait toujours la traction obtenue pour un même débit primaire, et ceci dans des proportions souvent importantes, puisque le gain de traction se situait souvent entre 0,5 et 1 Kg., voire même plus. Pour la tuyère "I62" par contre, on avait une diminution de traction ne dépassant pas 500 grammes en supprimant le divergent en plastique.

Ceci montre indiscutablement que les résultats obtenus sont des résultats par défaut (sauf peut-être pour la tuyère "I62").

Les résultats n'en demeurent pas moins extrêmement intéressants, comme le montre le graphique ci-joint. Nous avons tracé sur une même feuille la courbe donnant le rapport traction sur débit primaire en fonction de la pression d'arrêt pour un jet donnant une réaction directe, et le rapport obtenu expérimentalement pour certains essais sur des tuyères "22", "I64" et "302". On voit que les résultats expérimentaux se situent largement au-dessus des résultats théoriques. Il faut encore remarquer que la courbe théorique a été tracée pour une température d'arrêt de 290° Kelvin, c'est à dire 17° C., alors que les résultats expérimentaux ont été obtenus avec une température dans la chambre de la tuyère de 20° C. pour la tuyère "22", de 15° C. seulement pour la tuyère "I64", et de 10° C. seulement pour la tuyère "302".

Ces résultats déjà très éloquents sont donc encore des résultats par défaut, puisque le rapport traction sur débit diminue quand la température d'arrêt diminue, comme on le vérifie sur les tableaux précédemment cités dans ce rapport.

II. REMARQUE SUR LE RAPPORT ENTRE LE DEBIT TOTAL ET LA TRACTION.

On remarque qu'en général le produit de la vitesse de sortie par le débit total est plus élevé que la traction. La précision des mesures du débit total ne permet pas de conclure d'une façon sûre. Il faut remarquer que théoriquement la traction est égale au flux sortant de quantité de mouvement dirigée suivant l'axe de la tuyère, c'est à dire le flux sortant du divergent moins le flux entrant dans le convergent (air aspiré). En fait, ce dernier donnera une composante très faible suivant l'axe de la tuyère, parce que l'air aspiré a une vitesse oblique par rapport à l'axe de la tuyère, l'effet d'aspiration se faisant sentir assez loin de celui-ci.

D'autre part, la dissymétrie de l'écoulement fait que le débit total ne donne pas uniquement une quantité de mouvement dirigée suivant l'axe de la tuyère, mais aussi suivant des perpendiculaires à cet axe, donnant ainsi naissance à des couples difficiles à évaluer.

III. REMARQUE SUR LE ROLE DES CONDITIONS ATMOSPHERIQUES.

Ce rôle est prépondérant, surtout du point de vue température. On peut le constater sur la tuyère "22" où une série d'essais à l'ouverture au pas de 0,3 mm. a été faite deux fois dans des conditions très différentes. Le décalage des courbes correspondantes est très net.

plastic divergent always increased the traction obtained, for equal primary flow, and often very considerably since the traction gained was often from 0.5 to 1 Kg. and sometimes more. For nozzle "I62", on the other hand, the removal of the plastic divergent caused a reduction in traction of not more than 500 grams.

This shows definitely that the absolute values obtained were too low (except perhaps for nozzle "I62").

However, the results are none the less interesting, as will be seen from the accompanying graph. On the same sheet, we have plotted the curve giving the ratio of traction to primary flow as a function of stagnation pressure for a jet producing a direct reaction, and the ratio obtained experimentally in certain tests on nozzles, "22", "I64" and "302". We see that the experimental results lie far above the theoretical results. It should also be mentioned that the theoretical curve was plotted for a stagnation temperature of 280° Kelvin, i.e. 17° C., whereas the experimental results were obtained with a temperature in the nozzle chamber of 20° C. for nozzle "22", only 15° C. for nozzle "I64", and only 10° C. for nozzle "302".

These absolute values of these results, which are already most interesting, are thus, however, again too low, since the traction-flow ratio decreases when the stagnation temperature falls, as is confirmed by the tables mentioned previously in this report.

II. REMARKS CONCERNING THE RATIO OF TOTAL FLOW TO TRACTION.

We note in general that the product of the exit velocity and the total flow is higher than the traction. The accuracy of the total flow measurements is not sufficient to allow definite conclusions. It should be noted that theoretically the traction is equal to the emerging momentum flux in the direction of the axis of the nozzle, that is to say the flux emerging from the divergent minus the flux entering the convergent (induced air). In actual fact, the component derived from the latter will be very small along the axis of the nozzle, because the velocity of the induced air is oblique in relation to the nozzle axis owing to the fact that the suction effect is perceptible quite far from this axis.

In addition, owing to the dissymmetry of the flow the total flow produces a momentum which is not solely directed along the axis of the nozzle but also perpendicular to this axis, thus giving rise to torques which are difficult to evaluate.

III. REMARKS CONCERNING THE EFFECT OF ATMOSPHERIC CONDITIONS.

Atmospheric conditions, and particularly temperature, are of great importance. This can be seen on nozzle "22", with which a series of tests, at an opening by pitch of 0.3 mm., were made twice in very different conditions. The changed position of the corresponding curves is very definite.

IV. REMARQUE SUR LA TUYERE DU TYPE "L.A." .

Cette tuyère a fait l'objet d'essais dans les laboratoires des Usines CHAUSSON à Asnières (Seine, France). On trouvera plus loin les caractéristiques de cette tuyère, le schéma de l'installation du banc d'essais et les résultats obtenus.

V. CONCLUSIONS.

Certes, il serait possible de déterminer la meilleure tuyère en se plaçant uniquement sur le plan rendement pur. On pourrait ainsi déterminer dans une famille de tuyères le diamètre optimum au col pour une pression et une ouverture données, ou bien déterminer pour une tuyère l'ouverture optimum pour une pression donnée. On pourrait, naturellement, pour plusieurs tuyères de mêmes dimensions mais de profil différent, déterminer la meilleure pour un même réglage.

Mais si on veut considérer un point de vue pratique, il faut prendre en considération des paramètres matériels : encombrement, résistance des matériaux, prix de revient, etc....

Tous ces paramètres ne pourront être introduits que le jour où sera connu le rôle précis assigné à la tuyère, c'est à dire quand on passera à la réalisation, non plus d'un avant-projet, mais d'un prototype d'AERODYNE.

IV. REMARK CONCERNING THE "L.A." TYPE NOZZLE.

Tests were made of this nozzle in the laboratories of the CHAUSSON works, at Asnières (Seine, France). The characteristics of this nozzle will be given later, together with a diagram of the test bench installation, and the results obtained.

V. CONCLUSIONS.

It would of course be possible to determine which is the best nozzle purely from the point of view of efficiency. Thus we could, for one category of nozzles, establish the most favorable diameter of throat for a given pressure and opening, or else establish the best opening of a nozzle for a given pressure. We could also, for several nozzles of the same dimensions but different profiles, determine which gave the best results for the same adjustment.

But if we wish to take into account the practical point of view, we must consider the material parameters : bulk, resistance of materials, prime cost, etc...


All these parameters can only be introduced when we know the exact purpose for which the nozzle is destined, that is to say when we pass on to the realization not merely of a draft project, but of the prototype of an AERODYNE.

=====

SPERI-COANDA.

Comparison of experimental results.
and theoretical data.

$\frac{Traction}{Primary Air Flow} = \frac{I}{D}$



(Pressures)
Pressions en Kg/cm^2

- TUYERE "L.A." -

La tuyère "L.A." est une tuyère interne centrifuge. Elle a pour but de remplacer les ventilateurs centrifuges.

Elle peut s'employer simple ou double, c'est à dire avec l'aspiration d'un seul côté ou par deux côtés à la fois.

Elle fonctionne de la façon suivante :

- Au col de la tuyère se trouve la fente soufflante par où sort l'air primaire. La forte dépression qui se produit le long de la première facette, laquelle est orientée approximativement parallèlement à l'axe de la tuyère, aspire violemment l'air ambiant (air secondaire).
- L'ensemble du mélange air primaire et air secondaire suit alors la paroi qui est formée par la lèvre prolongée de la fente et se dirige d'une façon centrifuge vers la périphérie de la tuyère.
- L'autre paroi de la tuyère est formée par la pièce du milieu dont le profil joue un grand rôle, car il faut que l'espace engendré par la lèvre prolongée de la fente et la paroi de la pièce centrale présente toutes les qualités d'un divergent. A la sortie de cet espace et en partant de la périphérie de la tuyère se trouve placée une couronne portant des ailettes de profil approprié, lesquelles impriment au mélange un mouvement de rotation de façon à ce que l'ensemble puisse être collecté par un colimaçon. Si l'emplacement le permet, on peut remplacer ces ailettes par des ailes circulaires concentriques lesquelles, suivant l'application d'un des Brevets de la SFERI-COANDA (Fente épaisse), permettent de collecter tout cet air dans une chambre pour être dirigé ensuite à l'endroit voulu.

Il est bon de mentionner que suivant les besoins on peut, bien entendu, monter ces tuyères "L.A." en plusieurs étages.

- " L.A. " NOZZLE -

The "L.A." nozzle is an internal centrifugal nozzle. Its purpose is to replace centrifugal ventilators.

It can be used in single or double form, that is to say with induction of air on one side only or on both sides at once.

The nozzle functions in the following manner :

- The slot out of which is blown the primary air is located at the throat of the nozzle. The great depression which is produced along the first facet, which is roughly parallel to the axis of the nozzle, exerts an extremely strong suction effect on the surrounding air (secondary air).
- The resulting mixture of primary and secondary air then follows the wall which is formed by the extended lip of the slot, and proceeds centrifugally towards the periphery of the nozzle.
- The opposite wall of the nozzle is formed by a center piece whose profile is of great importance, because it is necessary that the space lying between the extended lip of the slot and the said center piece should have all the characteristics of a divergent. At the exit of this space, around the periphery of the nozzle, a ring of fins of suitable profile impart a rotational motion to the mixture so that this can be collected in a spiral element. If the position of the device allows it, these fins can be replaced by annular, concentric wings in which one of the SFERI COANDA patents is applied (wide slot), which enable all the air to be collected in a chamber from which it can then be directed to the desired point.

It should be mentioned that these "L.A." nozzles can also, if desired, be mounted in series.

SFERI COANDA

Nozzle } L.A.
Tuyère }



Fig. 1

Coupe x-x





Fig. 2

SFERI-COANDA MONTAGE D'ESSAI LA



SFERI - COANDA TUYERE LA-

REAL OPENING	0,08	0,08	0,08	0,2	0,2	0,4	0,4	0,4	0,4	0,7	0,7	0,7	0,7
mm													
PRESSURE FIRST CHAMBER $P_1 = \text{Kg/cm}^2$	3	3,3	4	2,9	4,1	3	4	4,3	1,6	2,05	3,1	4,05	
TEMPERATURE $\theta_1 = ^\circ\text{C}$	22	22	22	24,5	25,5	27	25	26	22,5	29	23	22	
PRIMARY AIR FLOW 1 Kg/s	<0,07	<0,07	<0,07	<0,07	<0,07	0,097	0,154	0,154	0,166	0,181	0,255	0,305	
PRESSURE SECOND CHAMBER $P_2 = \text{Kg/cm}^2$	2,9	3,150	3,9	2,8	4	2,9	3,9	4,2	1,55	1,95	3	3,950	
TEMPERATURE $\theta_2 = ^\circ\text{C}$	21,5	21,5	21,5	24	25	27	26	25,5	21,5	22	22	21,5	
PRIMARY AIR FLOW 2 Kg/s	<0,07	<0,07	<0,07	<0,07	<0,07	$\approx 0,1$	$\approx 0,16$	$\approx 0,16$	0,172	0,199	0,266	0,319	
TOTAL PRIMARY AIR FLOW Kg/s	<0,14	<0,14	<0,14	<0,14	<0,14	$\approx 0,197$	$\approx 0,314$	$\approx 0,314$	0,338	0,390	0,521	0,624	
TOTAL AIR FLOW Kg/s	0,870	0,905	1,01	1,400	1,630	1,760	2,15	2,43	1,98	2,16	2,62	3	
AIR INDUCTION RATIO	>6	>6,5	>7	>10	>11,5	$\approx 8,9$	$\approx 6,8$	$\approx 7,7$	5,9	5,5	5	4,8	
TEMPERATURE EXIT $\theta' = ^\circ\text{C}$	16	15,5	16	19	19,5	21,5	21	21,5	17	17	17	17,5	
ATMOSPHERIC TEMPERATURE $\theta_a = ^\circ\text{C}$	—	—	—	—	—	—	—	—	17	17	17	17,5	
ATMOSPHERIC PRESSURE mm/Hg	757	757	757	736	736	749	749	749	766	766	766	766	


SUC. 3/4 57

SFERI-COANDA.

Tuyère LA.7.A.

Prises de pressions sur les facettes

Echelle : 5/1



Echelle des pressions
1^m/m = 5^m/m Hg.

Ouv. ^m /m	Pressions
0.7	3 Kg/cm ²
0.7	4 Kg/cm ² ---x---
0.8	3 Kg/cm ² —●—

UNCLASSIFIED

**A
D 20407**

Armed Services Technical Information Agency

**ARLINGTON HALL STATION
ARLINGTON 12 VIRGINIA**

**FOR
MICRO-CARD
CONTROL ONLY**

5 OF 5

NOTICE: WHEN GOVERNMENT OR OTHER DRAWINGS, SPECIFICATIONS OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY RELATED GOVERNMENT PROCUREMENT OPERATION, THE U. S. GOVERNMENT THEREBY INCURS NO RESPONSIBILITY, NOR ANY OBLIGATION WHATSOEVER; AND THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED, FURNISHED, OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA IS NOT TO BE REGARDED BY IMPLICATION OR OTHERWISE AS IN ANY MANNER LICENSING THE HOLDER OR ANY OTHER PERSON OR CORPORATION OR CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

UNCLASSIFIED